389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To:	Paul Larochelle	**From:**	Mike Nugent
Fax:	885-0846	**Date:**	December 2, 2003
Phone	885-0855	**Pages:**	2
Re:	363 Fore St. 032 F005		

☐ **Urgent** ☐ **For Review** ☐ **Please Comment** ☑ **Please Reply** ☐ **Please Recycle**

In order to commence the review of the above project please submit :

1) Can you look at the type of construction again and advise if it's 5 or 3.
2) The structural plans referred for the floor systems need to be provided with loading calcs.
3) Can you confirm that the floor loading of the existing areas that are to remain will comply with Section 16 of the building code for this use group, also the storage/office.
4) Please provide a code justification for not providing a fire separation assembly between the A-3 use and the B use above.
5) Are there any concentrated laod concerns with the equipment intended?