## DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

ELEVEN EXCHANGE LLC

Located at

363 FORE ST (367)

**PERMIT ID:** 2016-00209

**ISSUE DATE:** 02/10/2016

CBL: 032 F005001

has permission to

Change of Use - Alterations, including relocating the bathroom to the rear and making ADA compliant. Frame two (2) additional walls to create a storage room and install 8 barber stations.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Department

/s/ Craig Messinger

/s/ Jeanie Bourke

Fire Official

**Building Official** 

# THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

\_\_

1st floor - retail and personal services

Use Group: B Type: 3B

Business - Barber Shop Occupant Load = 12 Nonsprinkled

First Floor

MUBEC/IBC 2009

# BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

# Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

# **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing w/Fire & Draft Stopping Electrical Close-in Certificate of Occupancy/Final Final - Electric Fire - Change of Use Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

#### Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 02/01/2016 2016-00209 032 F005001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: **Proposed Project Description:** Retail and personal services - Barber Shop Change of Use - Alterations, including relocating the bathroom to the rear and making ADA compliant. Frame two (2) additional walls to create a storage room and install 8 barber stations. **Dept:** Historic **Status:** Approved w/Conditions Reviewer: Deborah Andrews **Approval Date:** 02/03/2016 Ok to Issue: Note: **Conditions:** 1) Any exterior alterations associated with change of use--including the installation of new sign(s) requires Historic Preservation review and approval. 02/03/2016 **Dept:** Zoning **Status:** Approved w/Conditions Reviewer: Christina Stacey **Approval Date:** Note: B-3 zone, PAD Ok to Issue: **Conditions:** 1) Separate permits shall be required for any new signage. 2) This property is located in the Pedestrian Activities District (PAD) which regulates first floor uses to retail -like and other uses as listed in section 14-217(b)(1). The front windows shall not be blocked or have curtains that block out visibility from the sidewalk. Your use(s) shall not change without review and approval PRIOR to implementation Dept: Building Inspecti Status: Approved w/Conditions 02/09/2016 Reviewer: Jeanie Bourke **Approval Date:** Ok to Issue: Note: **Conditions:** 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) Penetrations in or through fire resistance rated assemblies shall be protected by an approved penetration firestop system installed as tested in accordance with ASTM E814 or UL 1479. Design specification cut sheets shall be submitted in electronic format for review and approval for each penetrating item. 3) Equipment shall be installed in compliance with the manufacturer's specifications and the UL listing. 4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. **Dept:** Engineering DPS **Status:** Not Applicable Reviewer: Rachel Smith 02/02/2016 **Approval Date:**

### **Conditions:**

1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov

**Dept:** Fire **Status:** Approved w/Conditions **Reviewer:** Craig Messinger **Approval Date:** 02/08/2016 **Note:** Ok to Issue: ✓

### **Conditions:**

- 1) Shall comply with NFPA 101, Chapter 36, New Mercantile Occupancies.
- 2) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.
- 3) Shall meet the requirements of 2009 NFPA 1 Fire Code.