STUDS 16" OC

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/16/16

GYPSUM BOARD APPLIED VERTICALLY.
JOINTS TO RECEIVE SHEETROCK TAPE
AND JOINT COMPOUND.

PARTITION - SINGLE LAYER JOINT

CONFIGURATION 1 HOUR WALL

SCALE: 1/4" = 1" DATE: 5/23/98

UNITED STATES GYPSUM COMPANY

This Gypsum Board Assembly detail must
not be used without a complete evaluation by owner's design professional
to verify the suitability of the design for a given structure.