



**Portland Fire Department**

8/6/2019

ELEVEN EXCHANGE LLC  
PO BOX 4894  
PORTLAND, ME 04112  
plewis01022000@yahoo.com

CERTIFIED MAIL

RE: 9 EXCHANGE ST APARTMENTS  
PORTLAND, ME

032 F010001

Page 1 of 2

**NOTICE OF VIOLATION  
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 8/6/2019 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

**A reinspection of your property will take place on 9/4/2019 12:00:00AM .**

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan  
Fire Prevention Bureau  
City of Portland

**NON-COMPLIANCE VIOLATION LIST**

<b>NAME</b>	<b>CODE DESCRIPTION</b>	<b>COMMENTS</b>	<b>Deadline</b>
PFD Rules, 5.10.2	All signal systems must have a current inspection sticker issued by a Master Fire Alarm Company.	Fire Alarm Certification Sticker expired 1/11/2019	2/7/2019