DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that **ELEVEN EXCHANGE LLC**

Located At <u>5 EXCHANGE ST</u>

Job ID: 2011-02-448-CH OF USE

CBL: 032 - - F - 012 - 001 - - - - -

has permission to install a hood suppression System

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be

Fire Prevention Officer

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY.

PENALTY FOR REMOVING THIS CARD

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2011-02-448-CH OF USE 2011-3009	Date Applied: 2/16/2011 4122 II		CBL: 032 F - 012 - 00	1			
Location of Construction: 7 EXCHANGE ST	Owner Name: ELEVEN EXCHANGE LLC		Owner Address: PO BOX 4894 PORTLAND, ME 04112			Phone:	
Business Name:	Contractor Name: D. Chapman - Firesafe Equipment		Contractor Address:			Phone: (207) 784-7525	
Lessee/Buyer's Name:	Phone:		Permit Type: Fire Suppression System			Zone: B-3	
Past Use: Restaurant – "Exchange Street Café"	Proposed Use: Restaurant – "Exchange Street Café" – fire suppression system		Cost of Work: 3000.00 Fire Dept: Approved w/ conditions Denied N/A Signature: Thursell. 58		CEO District: Inspection: Use Group: Type: Signature:		
Proposed Project Descriptio 7 Exchange St "Exchange St Caf Permit Taken By:			Pedestrian Activ	ities District (P.A.D.			
 This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building Permits do not include plumbing, septic or electrial work. Building permits are void if work is not started within six (6) months of the date of issuance. False informatin may invalidate a building permit and stop all work. 		to conform to all applicable laws of		this jurisdiction. In addition	Not in Di Not in Di Does not Requires Approved Approved Denied Date: Ary CALINGS And that I have been and if a permit for wo	e: Any extense work quires a separate New & aparoast the box preservation have been authorized by mit for work described in	
SIGNATURE OF APPLICAN	TT A	DDRESS		DATE	:	PHONE	
RESPONSIBLE PERSON IN	CHARGE OF WORK,	 TITLE		DATE		PHON	

BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Director of Planning and Urban Development

Penny St. Louis

Job ID: <u>2011-02-448-CH OF USE</u> Located At: <u>5 EXCHANGE ST</u> CBL: <u>032 - - F - 012 - 001 - - - - -</u>

Conditions of Approval:

Fire

Hood suppression system shall comply with NFPA 17A, 96, and UL 300. Activation of the suppression system shall activate the fire alarm system if available. A letter of compliance will be required at the time of final inspection stating: the date the system was tested for operation, fuel gas shut off, and fire alarm connection. The Class K fire extinguisher and proper signage should be located at the suppression system pull station.

Because of property and building set backs, and proximity to openings and vents, the duct work is required to terminate above the roof line per NFPA 96. Clean outs shall be provided.

Occupancy Type Code:

Structure Type Code

Stores & Customer Services (Mercantile) 6

Job Summary Report Job ID: 2011-02-448-CH OF USE

Report generated on Apr 26, 2011 10:29:56 AM Page 1 Change of Use 7 Exchange St "Exchange St Job Year: Job Type: **Job Description:** 2011 Commercial Cafe" Pin Value: **Building Job Status Code:** Approved 685 **Tenant Name:** Exchange St Cafe **Job Application Date:** Public Building Flag: Tenant Number: 3,000 **Estimated Value:** Square Footage: **Related Parties: EXCHANGE FLEVEN** Property Owner MIKE LOCKE PLUMBING CONTRACTOR KENNETH J. SANDERSON - KENNETH SANDERSON ELECTRICAL CONTRACTOR Firesafe Equipment - D Chapman SPRINKLER CONTRACTOR National Air & Refrigeration - Mike Iosua GENERAL CONTRACTOR **Job Charges** Fee Code Charge Permit Charge **Net Charge Payment** Receipt **Payment** Payment Adjustment Net Payment Outstanding Number Description Amount Adjustment **Amount** Date **Amount** Amount Amount **Balance** Location ID: 4706 **Location Details** Census Tract GIS X GIS Y GIS Z GIS Reference Longitude Latitude Alternate Id Parcel Number -70.253319 43.656679 S37187 032 F 012 001 М Location Type Subdivision Code Subdivision Sub Code Related Persons Address(es) 5 EXCHANGE STREET WEST **Inside Outside** District General Location Location Use Code Variance Use Zone Code Fire Zone **Inspection Area** Jurisdiction Code Code Code Code Code Code Code **RETAIL & PERSONAL** DOWNTOWN Historic DISTRICT 2 CENTRAL BUSINESS SERVICE BUSINESS District DISTRICT Structure Details Structure: Loc id 000004705 Alt id 000292

Address
5 EXCHANGE STREET WEST

Structure Status Type Square Footage Estimated Value

1263,24



Non-Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: TEXChings Shutt-	CBL: 32-F-12					
Exact location: (within structure)						
Type of occupancy(s) (NFPA & ICC):						
Building owner:						
Managing Supervisor:	License No:					
Supervisor phone: 205-7852	E-mail:					
Installing contractor: Fishafe Equipment	License No: Ma.					
Contractor phone: 307-184-1535.	_E-mail: <u>a Chapmena) tire-sate</u> com					
The suppression work to be done will be: New: Renovation: Addition to existing system:						
This is an amendment to an existing permit: Yes: NO Permit no:						
System Type: Lyst Shemical	COST OF WORK 9/900-					
NFPA Standard:Edition: COST OF WORK:						
*Non-NFPA systems are not approved for use within the City of Portland.	PERMIT FEE:					
Download a new copy of this document from						
www.portlandmaine.gov/fire for every submittal. Attach all working						
documents as required on electronic PDF's in addition to	{					
full sized plans.	}					
	NED					
Submit all information to the Building Inspections Department, 389 Congress Street, Room 375, Forward, Maine 24101.						
Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with						
Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with the all fire system contractors and the Fire Department, and proper documentation of such test(s) provided. All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).						
All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).						
Applicant signature:	_ Date:					