

ELECTRICAL PERMIT

City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical Code and the following specifications:

Date _____
 Permit # 2010-4811
 CBL# 32-G-1

LOCATION: 400 Congress METER MAKE & # _____
 CMP ACCOUNT # _____ OWNER A+m Partner's
 TENANT Keppure 4th fl. PHONE # 874 6959

						TOTAL EACH FEE	
OUTLETS	50	Receptacles	30	Switches		Smoke Detector	.20
FIXTURES	12	Incandescent	75	Fluorescent		Strips	.20
SERVICES		Overhead		Underground		TTL AMPS <800	15.00
		Overhead		Underground		>800	25.00
Temporary Service		Overhead		Underground		TTL AMPS	25.00
							25.00
METERS		(number of)					1.00
MOTORS		(number of)					2.00
RESID/COM		Electric units					1.00
HEATING		oil/gas units		Interior		Exterior	5.00
APPLIANCES		Ranges		Cook Tops		Wall Ovens	2.00
		Insta-Hot	2	Water heaters		Fans	2.00
		Dryers		Disposals		Dishwasher	2.00
		Compactors		Spa		Washing Machine	2.00
		Others (denote)					2.00
MISC. (number of)		Air Cond/win					3.00
		Air Cond/cent				Pools	10.00
		HVAC		EMS		Thermostat	5.00
		Signs					10.00
		Alarms/res					5.00
		Alarms/com					15.00
		Heavy Duty(CRKT)					2.00
		Circus/Carnv					25.00
		Alterations					5.00
		Fire Repairs					15.00
	10	E Lights					1.00
		E Generators					20.00
PANELS		Service		Remote		Main	4.00
TRANSFORMER		0-25 Kva					5.00
		25-200 Kva					8.00
		Over 200 Kva					10.00
						TOTAL AMOUNT DUE	
						MINIMUM FEE/COMMERCIAL	55.00
						MINIMUM FEE	45.00

RECEIVED

NOV 19 2010
 Dept. of Building Inspections
 City of Portland Maine

CONTRACTORS NAME Floridino Elec MASTER LIC. # MS60004234
 ADDRESS 35 Lawrence Ave. 04103 LIMITED LIC. # _____
 TELEPHONE 838 8277

SIGNATURE OF CONTRACTOR Mike Floridino

ELECTRICAL INSTALLATIONS—

Permit Number _____

Location _____

Owner _____

Date of Permit _____

Final Inspection _____

By Inspector _____

INSPECTION: Service _____ by _____

Service called in _____

Closing-in _____ by _____

PROGRESS INSPECTIONS:

_____	/	_____	/	_____
_____	/	_____	/	_____
_____	/	_____	/	_____
_____	/	_____	/	_____
_____	/	_____	/	_____
_____	/	_____	/	_____
_____	/	_____	/	_____

DATE:	REMARKS:
11/24/200	OK TO close in BKL
1/10/2011	Callig OK TO close, He will have tiles out BT water Heater AND Front entrance, AND A FEW LIGHTS, AND BT electrical room TO SC Groundy of Building steel wt # 4, Read old electrical panels, Bring Ground TO Termination Box For DATA Room BKL
1/31/2011	4 th Floor needs labeling For electrical Panels BKL
2/1/2011	4 th Floor Final OK (still waiting for electric room sign) OK TO close BKL

RECEIVED

Dept. of Building Inspections
City of Chicago