

NOTIFICATION APPLIANCE CIRCUIT VOLTAGE DROPS						
Kepware 120 Exchange St 3rd Floor						
Portland, Maine						
PANEL	CIRCUIT	LENGTH	CURRENT DRAW	VOLTAGE DROP	VOLTAGE LOSS	END VOLTAGE
FCPS	New	192 FT	.629A	0.61VDC	2.54%	23.39VDC
Calculated Using #14 AWG Wire @ Maximum Distance/Current						