

NOTIFICATION APPLIANCE CIRCUIT VOLTAGE DROPS						
A&M Partners - 120 Exchange Street 5th Floor						
Portland, Maine						
PANEL	CIRCUIT	LENGTH	CURRENT DRAW	VOLTAGE DROP	VOLTAGE LOSS	END VOLTAGE
FCPS	Spare	210 FT	0.797A	0.85VDC	3.54%	23.15VDC
Calculated Using #14 AWG Wire @ Maximum Distance/Draw						