



Reviewed for Code Compliance
Inspections Division
Approved with Conditions

NOTIFICATION APPLIANCE CIRCUIT VOLTAGE DROPS						
A&M Partners - 120 Exchange Street 5th Floor						
Portland, Maine						
PANEL	CIRCUIT	LENGTH	CURRENT DRAW	VOLTAGE DROP	VOLTAGE LOSS	ENI VOLT/
FCPS	Spare	210 FT	0.797A	0.85VDC	3.54%	23.15'
Calculated Using #14 AWG Wire @ Maximum Distance/Draw						

Date: 09/02/15