1 PROPOSED PLAN
1/8"=1'-0"

TYPICAL NEW WALL CONSTRUCTION
One Layer 5/8" Gypsum Board on each side of 3-5/8" steel stud spaced at 24" on center with fiberglass bat insulation

FCPS - Power Supply
S - SMOKE (2)
F - PULL
F - HORN STROBE (6)
S - STROBE (5)

E = Existing
C = Ceiling mount

Project North
W E
S

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 09/02/15

Prepared Fo

Consulting Engineer:

Architect: ARCHETYPE architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project: 5th FLOOR, OFFICE RENOVATION
400 CONGRESS STREET
PORTLAND, MAINE 04101

Revisions:

Date: June 3rd, 2015
Scale: AS NOTED

PROPOSED PLAN 5th FLOOR.

A1.01