Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 09/02/15

SYSTEM OUTPUTS

		CONTROL UNIT ACTIVATION								NOTIFICATION					REQUIRED FIRE SAFETY CONTROL			
		ACTIVATE COMMON ALARM SIGNAL INDICATOR	ACTIVATE AUDIBLE ALARM SIGNAL	ACTIVATE COMMON SUPERVISORY SIGNAL INDICATOR	ACTIVATE AUDIBLE SUPERVISORY SIGNAL	ACTIVATE COMMON TROUBLE SIGNAL INDICATOR	ACTIVATE AUDIBLE COMMON TROUBLE SIGNAL	DISPLAY ALPHA-NUMERIC SYSTEM STATUS MESSAGE	RECORD EVENTS IN THE SYSTEM MEMORY	ACTIVATE GENERAL EVACUATION SIGNALS	SEND FIREFIGHTERS WARNING SIGNAL TO ELEVATOR CONTROLS	TRANSMIT FIRE ALARM SIGNAL TO REMOTE ALARM RECEIVING STATION	TRANSMIT SUPERVISORY SIGNAL TO REMOTE ALARM RECEIVING STATION	TRANSMIT TROUBLE SIGNAL TO REMOTE ALARM RECEIVING STATION	RECALL ELEVATORS TO PRIMARY RECALL FLOOR	RECALL ELEVATORS TO ALTERNATE RECALL FLOOR	RELEASE DOOR HOLDERS	
SYSTEM INPUTS		A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	
1	MANUAL FIRE ALARM PULL STATION	●	●					●	●	●		●					●	1
2	AREA SMOKE DETECTOR	●	●					●	●	●		●					●	2
3	ELEVATOR LOBBY SMOKE DETECTOR - PRIMARY FLOOR	●	●					●	●	●		●				●	●	3
4	ELEVATOR LOBBY SMOKE DETECTOR - ALTERNATE FLOOR	●	●					●	●	●		●			●		●	4
5	NAC POWER SUPPLY AC POWER FAILURE					●	●	●	●					●				5
6	NAC POWER SUPPLY LOW BATTERY					●	●	●	●					●				6
7	OPEN CIRCUIT					●	●	●	●					●				7
8	GROUND FAULT					●	●	●	●					●				8
9	NOTIFICATION APPLIANCE CIRCUIT SHORT					●	●	●	●					●				9
10	SERVER ROOM SUPPRESSION SYSTEM DISCHARGE	●	●					●	●	●		●					●	10
		A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	

REVISION 0 SUBMITTAL	DATE: 07/30/2015
FACP ADDITION WIRING RISER	
PROJECT NAME **KEPWARE FIT UP** 400 CONGRESS STREET PORTLAND, ME	SCALE NTS BY: JRS CK BY: DG
NORRIS INC Prepared For Tomorrow; Delivered Today 2257 BROADWAY, SOUTH PORTLAND, MAINE	SAVED AS: