

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



This is to certify that  
RICH BUILDING LLC

Located at  
106 Exchange St

PERMIT ID: 2014-00479      ISSUE DATE: 05/01/2014      CBL: 032 H002001

has permission to **Sign for Timber Restaurant**  
**7' sq ft round.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*

*Building Inspections*

*Fire Department*

restaurant on 1st floor and lower level (was Oriental Table, now Timbers)

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2014-00479	<b>Date Applied For:</b> 03/11/2014	<b>CBL:</b> 032 H002001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-				
<b>Proposed Use:</b> Same: Restaurant on 1st floor & lower level		<b>Proposed Project Description:</b> Sign for Timber Restaurant 7' sq ft round.		
<b>Dept:</b> Historic <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Robert Wiener <b>Approval Date:</b> 04/30/2014 <b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/>				
<b>Conditions</b>				
1) The light fixture for the ceiling of the entry alcove must be reviewed and approved prior to installation. 2) No lighting is approved with this sign permit. If the applicant wishes to add lighting for the sign, HP staff must review and approve fixtures before installation, and staff strongly encourages the use of small spots integrated into the hanging system, with no exposed wiring or conduit. 3) Sign bracket location and attachment is not approved as proposed. Sign is to hang from steel bar projecting from the ceiling of the entry alcove - as already installed, and shown in photo uploaded to eplan 4/30/14.				
<b>Dept:</b> Zoning <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Marge Schmuckal <b>Approval Date:</b> 03/18/2014 <b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/>				
<b>Conditions</b>				
1) This property is located in a Historic District which requires a separate review for exterior work. 2) Separate permits are required for sidewalk signs.				
<b>Dept:</b> Building <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Tammy Munson <b>Approval Date:</b> 04/28/2014 <b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/>				
<b>Conditions</b>				
1) Signage and Awning Installation to comply with Chapters 16 (Structural Loads), 31 (Materials) & 32 (ROW Height & Encroachments) of the IBC 2009 building code. 2) Encroachments into public ways must be a minimum of 8' above grade for signs and 7' for awnings per section 3202 of IBC 2009. 3) The sidewalk sandwich sign shall not infringe on the City Right of Way 4) Separate Permits shall be required for any new signage.				