

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

RICH BUILDING LLC /Mainetainers

Located at

106 EXCHANGE ST

PERMIT ID: 2014-00019

ISSUE DATE: 02/11/2014

CBL: 032 H002001

has permission to **INTERIOR TENANT FIT-UP FOR 'TIMBER' RESTAURANT TENANT.
WORK TO INCLUDE NEW INTERIOR TENANT FIT-UP, EXISTING
KITCHEN TO REMAIN (EXISTING EXHAUST HOOD TO REMAIN) & 'ADA'
RESTROOMS AS SHOWN.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

Fire Official

/s/ Jeanie Bourke

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

restaurant on 1st floor and lower level
(was Oriental Table, now Timbers)

Building Inspections

Use Group: A-2 **Type:** 3B
Assembly - Restaurant First Floor
Occupant Load 91
Basement - Storage Only
Residential/Business - Floors 2, 3 & 4

Fire Department

MUBEC/IBC 2009

PERMIT ID: 2014-00019

Located at: 106 EXCHANGE ST

CBL: 032 H002001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Above Ceiling Inspection

Final - Commercial

Final - Electric

Final - Fire

Pre-Construction Meeting

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-00019	Date Applied For: 01/06/2014	CBL: 032 H002001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Restaurant 1st floor & Storage lower level (Timber)		Proposed Project Description: INTERIOR TENANT FIT-UP FOR 'TIMBER' RESTAURANT TENANT. WORK TO INCLUDE NEW INTERIOR TENANT FIT-UP, EXISTING KITCHEN TO REMAIN (EXISTING EXHAUST HOOD TO REMAIN) & 'ADA' RESTROOMS AS SHOWN.		
Dept: Historic	Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 01/15/2014	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) No exterior alterations are approved with this permit. Any exterior alterations, including new signs must be reviewed under a separate application.				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Marge Schmuckal	Approval Date: 01/10/2014	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Separate permits are required for any new signage.				
Dept: Building	Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 02/11/2014	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) Any modifications to existing building systems and all new systems (HVAC, electrical, plumbing) shall meet IECC 2009 or ASHRAE 90.1-2007 requirements for energy code compliance.				
3) Approval of City license is subject to health inspections per the Food Code.				
4) Approval is subject to compliance with City and State Food Codes per the Portland Public Health Dept. It is strongly advised to contact the Health Inspector for approval of kitchen design compliance prior to commencing work in earnest.				
5) Equipment shall be installed in compliance with the manufacturer's specifications and the UL listing.				
6) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 01/25/2014	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) All means of egress to remain accessible at all times.				
2) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.				
3) Shall comply with 2009 NFPA 101, Chapter 12, New Assembly Occupancies.				
4) All construction shall comply with City Code Chapter 10.				