



# Fire Suppression System Design Specificatio

Reviewed for Code Compliance  
Inspections Division  
Approved with Conditions

## Notes

## System Ma

Date: 01/25/14

Item Number	Description	
87-120016-001	ADP Nozzle	2
87-120017-001	F Nozzle	2
87-120020-001	DM Nozzle	1
87-120019-001	R Nozzle	1
60-120073-001	1 1/4" NPT Mechanical Gas Valve	1
60-120110-001	Remote Manual Release, Combination	1
60-120005-001	WHDR-600 Cylinder/Valve, 6 Gallon	1
60-120099-001	Universal Control Head Assembly	1
WK-282664-000	ML-360 Link 360 F (182 C), ML, Unpaint	2
WK-282666-000	ML-500 Link 500 F (260 C), ML, Orange	5
60-120064-001	Universal Link Detector Housing Kit (A+	7



Designed & Installed by:  
Firesafe Equipment  
PO Box 1355  
Auburn, ME 04211  
207-784-7525

For:  
TIMBERS