COPYRIGHT: Reuse or reproduction of the contents of this document is not permitted without written permission of Bild Architecture LLC

| | |
|---|---|
| 2H | 2X4 WOOD FRAMING FIRE WALL 2 HOUR RATED UL-U301 ASSEMBLY |
| 6" | ACTUAL WALL THICKNESS |

| | |
|---|---|
| 2X | EXISTING CMU WALL |
| 7 5/8" | ACTUAL WALL THICKNESS |

## WALL TYPES

WALL TYPE NOTES:
ALL INTERIOR WALLS ARE EXISTING UNLESS NOTED OTHERWISE

| | |
|---|---|
| A | 2X4 METAL FRAMING ACOUSTICAL WALL |
| AP | 2X8 METAL FRAMING ACOUSTICAL WALL |

11 A1.1 A2.1 PLATFORM SECTION
0 2'-0" SCALE: 1/2" = 1'-0"

10 A1.1 A2.1 TYPICAL STAIR DETAIL
0 2'-0" SCALE: 1/2" = 1'-0"

33 A1.1 A2.1 HEAD OF WALL TO CEILING
0 0'-8" SCALE: 1 1/2" = 1'-0"

Bild Architecture
PO Box 8235
Portland, ME
04104
207.408.0168
evan@bildarchitecture.com

LICENSED ARCHITECT EVAN A. CARROLL No. 3987 STATE OF MAINE
11/21/14

Reviewed for Code Compliance Inspections Division Approved as Noted
Date: 01/30/15

PROJECT NO.
14034
PROJECT NAME
TEMPLE STREET MUSIC VENUE

REVISIONS
1 | -01/23/15
2 | -
3 | -
4 | -
5 | -

PERMITTING DOCUMENTS

DRAWN BY
EAC
SHEET TITLE
DETAILS

ISSUE DATE
11/21/14
SHEET SCALE
1/4" = 1'-0"

A
2.1