CITY OF PORTLAND, MAINE



Department of Building Inspection

Certificate of Occupancy

LOCATION

96 FEDERAL ST

CBL 032 H004001

Issued to

City Of Portland/Old Port Playhouse /Michael Tobin

Date of Issue

10/09/2009

— changed as to use under Building Permit No.

Observable 100 - 1019 has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Old Port Playhouse

APPROVED OCCUPANCY

Theatre

Use Group A-1

Mezzanine Occupant Load 10

Limiting Conditions:

Temporary until 11/9/09 for sprinkler protection in boiler room and additional emergency lighting. Total

Occupant Load restricted to 50.

This certificate supersedes

certificate issued Bon Wallece - P

Approved:

10-9-09

(Date)

inspector

MELL

Inspector of Buildings

Notice: This certificate identifies inwful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.