NFPA 13R sprinkler check list

- ☐ Is this check list applicable? No
- ☐ What edition of NFPA 13R is the designed to'
- ☐ Building construction type: _____
- ☐ Will the sprinkler system provide complete or
- ☐ Will covered exterior balconies, decks and gr
- ☐ Size of riser assembly: _____
- ☐ Fire department connection- number of 2 ½" i
- ☐ Electrical supervision will be provided via the
- ☐ Is the nearest fire hydrant within 100 ft. of the
- ☐ The completed *Contractor's Material and Tes* the completion of the job? _____

RESURGAM. CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 12/14/16

NFPA 13 sprinkler check list

- ☐ Is this check list applicable? Yes
- ☐ What edition of NFPA 13 is the designed to? 2016
- ☐ Building construction type: Brick & Wood
- ☐ Will the sprinkler system provide complete or partial coverage of the building? Complete
- ☐ System type (See NFPA 13:3.4): Wet
- ☐ NFPA 13 Occupancy Classification (Hazard): Light
- ☐ Is the structure high-rise (see NFPA 101:3.3.32.7)? No
- ☐ Size of riser assembly: 4"
- ☐ Fire department connection- number of 2 ½" inlets: 2
- ☐ Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: Yes
- ☐ Is the nearest fire hydrant within 100 ft. of the FDC? Yes
- ☐ The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? Yes

NFPA 14 standpipe check list

- ☐ Is this check list applicable? No
- ☐ What edition of NFPA 14 is the designed to? _____

Building Inspections Division · 389 Congress Street · Portland, Maine 04101 · (207) 874-8703 · FACSIMILE (207) 874-8716 · TTY (207) 874-8936