

DEAN & ALLYN, INC.

FIRE PROTECTION • SPECIAL HAZARD

116 LEWISTON ROAD
GRAY, ME 04039
TEL. 207/657-5646 FAX 207/657-5647

September 11, 2018

CAP Services, Inc.
21 Schuster Rd
Cumberland, ME 04021

Attn: Tom Munroe, Project Manager

Re: Machias Savings Bank 4th Fl Renovation
Portland, ME
Automatic Fire Sprinkler Compliance Letter

Dear Mr. Munroe,

This letter serves as Dean & Allyn's statement of compliance regarding the work required to renovate the existing automatic fire sprinkler system for the referenced project. All work provided was done in accordance with the requirements of NFPA 13 and local & state codes.

The subject work primarily involved relocating sprinkler heads for new renovations to an existing light hazard occupancy per NFPA 13.

The existing feed and floor control valves supplying the subject space remained unchanged and left in service at the time of this statement.

Sincerely,

Dean & Allyn, Inc.



Derek Narvaez
Estimator