

Laurie Leader - RE: BP#2015-01796 50 Exchange Street - Plan review comments

From: <jonni@signarama-saco.com>
To: "Laurie Leader" <LRL@portlandmaine.gov>, <n_ros79@hotmail.com>
Date: 9/14/2015 4:27 PM
Subject: RE: BP#2015-01796 50 Exchange Street - Plan review comments

Hi Laurie,

The sign bracket is a steel power coated frame designed from bigger signs than the actual weight and size of this sign. The bracket has a 6" x 14" foot print which attaches to the brick face of the building using six 5/16 lag screws and anchors.

All hardware will be Stainless steel or Galvanized coated.

Please let me know if you need any other information.

Thank you!

Jonni Peace

Owner

Signarama

872 Portland Rd

Saco, ME 04072

207-494-8085

www.signarama-saco.com

Signarama
The way to grow your business.

From: Laurie Leader [mailto:LRL@portlandmaine.gov]
Sent: Monday, September 14, 2015 12:59 PM
To: n_ros79@hotmail.com; jonni@signarama-saco.com
Subject: BP#2015-01796 50 Exchange Street - Plan review comments

Nicole and Jonni,

I am handling the plan review for the sign for the above address. Can you please send me an attachment detail for the sign attaching to the building?

Thanks,

Laurie

Laurie Leader
Plan Review/Code Enforcement
City of Portland, Maine
Inspections Division
389 Congress Street
Portland, ME 04101

P: 207-874-8714

F: 207-874-8716

E: lrl@portlandmaine.gov

To view building permit status go to <http://www.portlandmaine.gov/792/Permit-Status>