

## Lauren Swett

---

**From:** Timothy Hart <thart@canal5studio.com>  
**Sent:** Wednesday, September 14, 2016 8:33 AM  
**To:** 'Sonia.barrantes@ripcordengineering.com'; Lauren Swett  
**Subject:** RE: Canal Plaza Update

Sonia, Lauren  
See email below.  
Looks like we have some data. Let's roll. Let me know if you need more.  
Tim

## CANAL5STUDIO

### Timothy Hart

One Canal Plaza, Suite 888  
Portland, Maine 04101  
207.553.2115 Ext.101

canal5studio.com

Architecture / Planning / Interior Design



---

**From:** Todd Dominski [mailto:tdominski@eastbrowncow.com]  
**Sent:** Wednesday, September 14, 2016 8:04 AM  
**To:** David Thomas <DThomas@consigli.com>; Timothy Hart <thart@canal5studio.com>  
**Cc:** sonia.barrantes@ripcordengineering.com; Tim Soley <tsoley@eastbrowncow.com>  
**Subject:** FW: Canal Plaza Update

See below from Jamie Cough at CMP.

Todd L. Dominski

---

**From:** Cough, Jamie [mailto:Jamie.Cough@cmpco.com]  
**Sent:** Wednesday, September 14, 2016 5:48 AM  
**To:** Todd Dominski  
**Cc:** [bhm@bhmilliken.com](mailto:bhm@bhmilliken.com)  
**Subject:** RE: Canal Plaza Update


Todd:

This is our tentative plan-we will confirm with our survey in the next few days.

Looking at the mole racks, we will come out of MH 05 which is directly in front of their proposed building.

The mole diagrams show space for a set of 500cu secondaries from there. That should be enough to get your team started on planning their conduit placement.

We only need one set of 500Cu, but I would suggest at least a 4-way 4" that leaves a couple spare for us, and probably one for fiber.



Jamie Cough  
Central Maine Power Company  
162 Canco Road  
Portland, ME 04103  
207-842-2367 (office)  
207-458-0382 (cell)  
207-626-4082 (fax)

---

**From:** Todd Dominski [<mailto:tdominski@eastbrowncow.com>]  
**Sent:** Tuesday, September 13, 2016 2:13 PM  
**To:** Cough, Jamie  
**Cc:** [bhm@bhmilliken.com](mailto:bhm@bhmilliken.com)  
**Subject:** Re: Canal Plaza

Jamie,  
Do you know when we might hear something back on the transformer in Canal Plaza. The architect is trying to finish up the drawings.

Todd L. Dominski

Sent from my iPhone

On Sep 2, 2016, at 7:24 AM, Cough, Jamie <[Jamie.Cough@cmpco.com](mailto:Jamie.Cough@cmpco.com)> wrote:

Todd:

I am waiting on our underground crew. I will f/up next week.

Jamie

Jamie Cough  
Central Maine Power Company  
162 Canco Road  
Portland, ME 04103  
207-842-2367 (office)  
207-458-0382 (cell)  
207-626-4082 (fax)

=====

Please consider the environment before printing this email.

If you have received this message in error, please notify the sender and immediately delete this message and any attachment hereto and/or copy hereof, as such message contains confidential information intended solely for the individual or entity to whom it is addressed. The use or disclosure of such information to third parties is prohibited by law and may give rise to civil or criminal liability.

The views presented in this message are solely those of the author(s) and do not necessarily represent the opinion of Iberdrola USA Networks, Inc. or any company of its group. Neither Iberdrola USA Networks, Inc. nor any company of its group guarantees the integrity, security or proper receipt of this message. Likewise, neither Iberdrola USA Networks, Inc. nor any company of its group accepts any liability whatsoever for any possible damages arising from, or in connection with, data interception, software viruses or manipulation by third parties.

=====