CERTIFICATE OF FLAME RETARDANCE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/12/16

ISSUED TO: ATLANTIC AWNING
270 FRANKLIN ST.
MELROSE, MA 02176
USA

REGISTERED
STATE OF CALIFORNIA
STATE FIRE MARSHAL
FLAME RETARDANT
GA - 1201.01

P.O. No. FAT FACE

NUMBER: 64302

DATE: 2/9/2016

THIS CERTIFICATE OF COMPLIANCE IS ISSUED TO VERIFY THAT THE ITEMS OR AREAS DESCRIBED BELOW ON THIS CERTIFICATE HAVE BEEN TREATED WITH FLAMECOAT (TM). FLAMECOAT IS A CLASS A FIRE RETARDANT.

Qty	Description of Material, Structure, Etc.
10	YARDS 85002 60' UNITY CHAR TREATED W/FLAMECOAT: NFPA 701 SMALL SCALE, ASTME-84 CLASS A, FLAME SPREAD: 10, SMOKE DENSITY: 25, CALIFORNIA TITLE 19 section 1237, CALIFORNIA TB 117-2013 FOR INTERIOR & OUTDOOR USE
1	SUPPLIES/HANDLING
1	SHIPPED VIA UPS 1Z3502W1 03 5898 5564

AMERICAN FLAMECOAT INC.

520 Eagleton Downs Drive - D
Pineville, NC 28134
O: 704.405.2550
F: 704.543.9772
www.americanflamecoat.com

Note: Fabrics and/or materials described on this certificate are intended for interior use unless otherwise stated.
Due to the number of external forces that can diminish flame retardancy, this fabric should be periodically retested to insure it retains its effectiveness.
We do not warrant the length of time that the fabric remains fire retardant. We do state that when it leaves our facility, it meets the stated code.
Certificate void if material is exposed to open flame or extremely hot lights or electrical wiring.