PARTITION SCHEDULE

"A"	FURRING CHANNEL
"B"	2 1/2" METAL STUD
"C"	3 5/8" METAL STUD
"D"	6" METAL STUD
1	DENOTES GWB ONE SIDE
2	DENOTES GWB TWO SIDES
3	DENOTES (2) LAYERS 0F 1/2" GWB ON ONE SIDE AND (1) LAYER of 5/8" GWB ON THE OTHER
4	DENOTES (2) LAYERS GWB ON EACH SIDE
S	DENOTES METAL STUDS TO EXTEND TO UNDERSIDE OF DECK ABOVE. GWB TO EXTEND TO 6" ABOVE CEILING. SEE DETAIL 5.
F	DENOTES METAL STUDS TO EXTEND TO UNDERSIDE OF DECK ABOVE. GWB TO EXTEND TO UNDERSIDE OF DECK ABOVE. SEE DETAIL 7.
X	DENOTES METAL STUDS TO EXTEND TO 6" ABOVE FINISH CEILING. TOP OF PARTITION TO BE DIAGONALLY BRACED BACK TO STRUCTURE. SEE DETAIL 6.

EXAMPLE:
C2S DENOTES 3 5/8" METAL STUDS WITH GWB ON BOTH SIDES. THE GWB SHOULD EXTEND TO 6" ABOVE THE ADJACENT CEILINGS.

-ALL PARTITIONS TO BE C2S U.O.N.
-PROVIDE PARTITION A1F AT ALL EXISTING WALLS U.O.N.
-PROVIDE MOISTURE RESISTANT GWB AT ALL TILE SURFACES. REFER TO FINISH PLAN
- ALL PARTITIONS TO RECEIVE 3" THERMAFIBER SAFB, FULL STUD THICKNESS U.O.N
- GWB TO BE 5/8" THICK UNLESS OTHERWISE NOTED.

SHEET NOTES

1. METAL STUD SPACING TO BE 16" O.C., MAX.
2. METAL STUD GAUGE (THICKNESS) AND SPACING SHALL COMPLY WITH INFORMATION FROM THE MANUFACTURER, THE GYPSUM ASSOCIATION OR INFORMATION CONTAINED IN THE LATEST EDITION OF THE STEEL STUD MANUFACTURER'S ASSOCIATION (SSMA) MANUAL. STUD GAUGE AND SPACING SHALL BE DESIGNED TO ALLOW A MAXIMUM DEFLECTION OF L/360 FOR ANY PARTITION TO HAVE CERAMIC TILE APPLIED, OR L/240 FOR ALL OTHER PARTITIONS.

   PROVIDE CALCULATIONS PREPARED BY LICENSED PROFESSIONAL ENGINEER.
3. IF PARTITION IS FIRE-RATED, MATCH MINIMUM STUD GAUGE AND SPACING TO MATCH THE REQUIREMENTS OF THE FIRE TEST.
4. PROVIDE ALL REQUIRED LATERAL BRACING RECOMMENDED BY THE MANUFACTURER, AND INSTALL PER THE MANUFACTURER'S INSTRUCTIONS. ADDITIONALLY PROVIDE LATERAL BRACING WHEN SUPPORTING MILLWORK AND AT DOOR JAMBS.



12 PERIMETER POCKET DETAIL
ID-800 SCALE: 1 1/2" = 1'-0"



11 ACTIVATION MAT/ CARPET TILE
ID-800 SCALE: 3" = 1'-0"



10 CARPET/ TILE TRANSITION
ID-800 SCALE: 3" = 1'-0"



7 HEAD @ FULL HEIGHT GWB
ID-800 SCALE: 3" = 1'-0"



6 ALTERNATE
HEAD @ GWB 6" ABOVE CEILING
ID-800 SCALE: 3" = 1'-0"



5 HEAD @ GWB 6" ABOVE CEILING
ID-800 SCALE: 3" = 1'-0"



4 FRAMING TYPE "D"
ID-800 SCALE: 3" = 1'-0"



3 FRAMING TYPE "C"
ID-800 SCALE: 3" = 1'-0"



2 FRAMING TYPE "B"
ID-800 SCALE: 3" = 1'-0"



1 FRAMING TYPE "A"
ID-800 SCALE: 3" = 1'-0"

KLING STUBBINS
2301 Chestnut Street
Philadelphia, Pennsylvania
19103

P 215.569.2900
F 215.569.5963
W www.klingstubbins.com

Fidelity's Engineering Consultant :
RDK ENGINEERS
Richard D. Kimball Company, Inc.
Seaport Center
Boston, MA 02210-1964

P 617-345-9885
F 617-345-4226
W www.rdkengineers.com

Seals:

Joseph A. Castner, Maine License No. 3583

General Notes:

Project Title:
Fidelity INVESTMENTS
Fidelity Real Estate Company
245 Summer Street
Boston, MA20110

Fidelity Investor Center
3 Canal Plaza
Portland, ME 04112
Branch ID No. 120

Number	Description	Date
	ISSUED FOR PERMIT & CONST	03 OCT 14

Key Plan: Project North



CAD File: POR_ID-800.dgn
Project No.: K2812515 R24
Copyright: 2014 KlingStubbins, Inc or LLC

Drawing Sheet Title :
PARTITION , FLOOR BASE, TRANSITION AND CEILING DETAILS

Drawing Sheet Number:
ID-800

Owner's Drawing Sheet No.:

K:\K2\K2812515\R24 Portland ME Expansion\Design\1_Disciplines\Interior\POR_ID-800 (partitions).dgn
kmackenzie
Printed on Tuesday September 30 2014 at 12:06PM