Billing Name: Sprinkler Systems Inc.

Address: P.O. Box 1285
Lewiston, ME 04243

Contact Person: Donna Giroux
Tel: (207) 782-0104
Email: Donna@sprinklersystemsinc.com

DATE:
TIME:
TESTE
SERV
WO #

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/19/15

Flow Hydrant: **POD-HYD00464**

Static: 90 psi
Pitot: 64 psi
Flow: 1342 GPM

Test Hydrant: **POD-HYD00415**

Static: 101 psi
Residual: 99 psi

Union Street
Portland

Scale 0 50 100 150 200 Feet 1 inch = 100 feet

Legend

Air Valve	Connection	Combined Service	Manhole
Blow Off	Attribute Change	Domestic Service	CSO
By Pass	Reducer	Fire Service	Gravity
Distribution	Hydrant	Private Hydrants	Force
Transmission	Hydrant Control	Meter Pits	

Disclaimer: This map is suitable for preliminary study and analysis and is based on PWD record information. PWD is not liable for any damages whatsoever resulting from inaccurate data or from errors made in the location and marking of its infrastructure.

PORTLAND WATER DISTRICT
225 Douglass Street
PO Box 3553
Portland, ME 04104
Telephone: (207) 774-5961
Fax: (207) 761-8307

Drawn By: BSJ

Prepared for: Alan Small
Sprinkler Systems Inc.

Test Fee: $170.00

Date: May 11, 2013