

# Water Supply Curve C

SPRINKLER SYSTEMS INC.  
3 CANAL PLAZA THIRD FLOOR AREA 1

Page 6  
Date

Pump Data:  
P1 - Pump Churn Pressure : 141  
P2 - Pump Rated Pressure : 130  
P2 - Pump Rated Flow : 506  
P3 - Pump Pressure @ Max Flow : 119  
P3 - Pump Max Flow : 750

Demand:  
D1 - Elevation : 20.139  
D2 - System Flow : 291.307  
D2 - System Pressure : 114.335  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 291.307  
Safety Margin : 22.904

