



. . . Fire Protection by Computer Design

Sprinkler Systems Inc.
2-4 Avon Street
P O Box 1285
Lewiston, Maine 04240
207-782-0104

Job Name : NORMAN HANSON DETROY
Building :
Location : 2 CANAL PLAZA, PORTLAND, MAINE 04101
System : 1 OF 1
Contract : 13011
Data File : 13011NORMANHANSONDETROYA1.WXF

Hydraulic Design Information Sheet

Name - NORMAN HANSON DETROY Date - 5-7-2013
 Location - 2 CANAL PLAZA, PORTLAND, MAINE 04101
 Building - System No. - 1 OF 1
 Contractor - MONAGHAN WOODWORKS Contract No. - 13011
 Calculated By - SCOTT E. GARLAND Drawing No. - 1, 2 OF 2
 Construction: () Combustible (X) Non-Combustible Ceiling Height - 8-6
 Occupancy - LIGHT HAZARD - OFFICES

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

Specific Ruling	Made By	Date
M Area of Sprinkler Operation - 900	System Type	Sprinkler/Nozzle
Density - .10	(X) Wet	Make RELIABLE
D Area Per Sprinkler - 225	() Dry	Model F1FR56
E Elevation at Highest Outlet - 159.667	() Deluge	Size 1/2 X 1/2
S Hose Allowance - Inside -	() Preaction	K-Factor 5.6
I Rack Sprinkler Allowance -	() Other	Temp.Rat.155 DEG
G Hose Allowance - Outside - 100		

N Note DESIGN AREA #1 - 4TH FLOOR OFFICES

Calculation Flow Required - 144.014 Press Required - 75.421 AT BASE OF RISER
 Summary C-Factor Used: 120 Overhead 140 Underground

Water Flow Test:	Pump Data:	Tank or Reservoir:
A Date of Test - 6-24-2008		Cap. -
T Time of Test -	Rated Cap.-	Elev.-
E Static Press - 90	@ Press -	
R Residual Press - 88	Elev. -	Well
Flow - 1758		Proof Flow
S Elevation - 117.0		

U Location - ON EXCHANGE STREET, 1500-0 FROM THE BUILDING

P Source of Information - PORTLAND WATER DISTRICT

Commodity	Class	Location
Storage Ht.	Area	Aisle W.
Storage Method:	%	Palletized % Rack
() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S R () Double Row	() Slave Pallet	() Solid Shelf () Non
T A () Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G Horizontal Barriers Provided:

Fittings Used Summary

Sprinkler Systems Inc.
NORMAN HANSON DETROY

Page 3
Date 5-7-2013

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Sprinkler Systems Inc.
 NORMAN HANSON DETROY

Page 4
 Date 5-7-2013

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
TYP	0.0	5.6	7.08	na	14.9	0.1	149	7.08
TYP1	0.0	8	17.02	na	33.0	0.1	330	17.0
1	159.667	K = K @ DROP	12.16	na	18.52			
2	159.667	K = K @ DROP	12.38	na	18.69			
3	159.667	K = K @ DROP	13.23	na	19.31			
4	159.667	K = K @ DROP	15.05	na	20.6			
A	159.667		18.3	na				
B	159.667		21.54	na				
5	159.667	K = K @ DRP1	20.47	na	33.0			
6	159.667	K = K @ DRP1	21.58	na	33.89			
E	159.667		25.71	na				
C	159.667		26.69	na				
D	159.667		29.24	na				
F	159.667		30.27	na				
G	159.667		35.94	na				
H	159.667		43.68	na				
S	109.167		65.97	na				
T	109.167		66.23	na				
U	109.167		66.65	na				
RT	108.0		67.42	na				
TV	105.083		71.7	na				
RB	101.75		75.42	na				
X1	101.75		75.9	na	100.0			
X2	101.75		75.93	na				
X3	117.0		69.38	na				
TEST	117.0		69.53	na				

The maximum velocity is 15.15 and it occurs in the pipe between nodes 4 and A

Final Calculations - Hazen-Williams

Sprinkler Systems Inc.
NORMAN HANSON DETROY

Page 5
Date 5-7-2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TYP to DROP	14.90 14.9	1.049 120.0 0.0755	2E 1T	4.0 5.0 0.0	1.500 9.000 10.500	7.080 0.0 0.793			K Factor = 5.60	
	0.0 14.90								Vel = 5.53	
						7.873			K Factor = 5.31	
TYP1 to DRP1	33.00 33.0	1.049 120.0 0.3286	2E 1T	4.0 5.0 0.0	1.500 9.000 10.500	17.016 0.0 3.450			K Factor = 8.00	
	0.0 33.00								Vel = 12.25	
						20.466			K Factor = 7.29	
1 to 2	18.52 18.52	1.442 120.0 0.0240		0.0 0.0 0.0	9.125 0.0 9.125	12.164 0.0 0.219			K Factor @ node DROP	
									Vel = 3.64	
2 to 3	18.69 37.21	1.442 120.0 0.0872		0.0 0.0 0.0	9.667 0.0 9.667	12.383 0.0 0.843			K Factor @ node DROP	
									Vel = 7.31	
3 to 4	19.31 56.52	1.442 120.0 0.1888		0.0 0.0 0.0	9.667 0.0 9.667	13.226 0.0 1.825			K Factor @ node DROP	
									Vel = 11.10	
4 to A	20.61 77.13	1.442 120.0 0.3356		0.0 0.0 0.0	9.667 0.0 9.667	15.051 0.0 3.244			K Factor @ node DROP	
									Vel = 15.15	
A to B	0.0 77.13	1.442 120.0 0.3357		0.0 0.0 0.0	9.667 0.0 9.667	18.295 0.0 3.245				Vel = 15.15
B to C	0.0 77.13	1.442 120.0 0.3356	1T	7.432 0.0 0.0	7.917 7.432 15.349	21.540 0.0 5.151				Vel = 15.15
	0.0 77.13									
						26.691			K Factor = 14.93	
5 to 6	33.00 33.0	1.442 120.0 0.0698		0.0 0.0 0.0	16.000 0.0 16.000	20.466 0.0 1.117			K Factor @ node DRP1	
									Vel = 6.48	
6 to E	33.89 66.89	1.442 120.0 0.2579		0.0 0.0 0.0	16.000 0.0 16.000	21.583 0.0 4.126			K Factor @ node DRP1	
									Vel = 13.14	
E to D	0.0 66.89	1.442 120.0 0.2579	1T	7.432 0.0 0.0	6.250 7.432 13.682	25.709 0.0 3.528				Vel = 13.14
	0.0 66.89									
						29.237			K Factor = 12.37	
C to D	77.13 77.13	2.157 120.0 0.0472	4E 1T	24.613 12.307 0.0	17.000 36.920 53.920	26.691 0.0 2.546				Vel = 6.77
D to F	66.88 144.01	2.157 120.0 0.1499		0.0 0.0 0.0	6.917 0.0 6.917	29.237 0.0 1.037				Vel = 12.64
F to G	0.0 144.01	2.157 120.0 0.1499	1T	12.307 0.0 0.0	25.458 12.307 37.765	30.274 0.0 5.661				Vel = 12.64

Final Calculations - Hazen-Williams

Sprinkler Systems Inc.
NORMAN HANSON DETROY

Page 6
Date 5-7-2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
G to H	0.0 144.01	2.157 120.0 0.1499	1B 7.384 1E 6.153 1Fsp 0.0 1T 12.307	5.792 25.844 31.636	35.935 3.000 4.743		* Fixed loss = 3 Vel = 12.64		
H to S	0.0 144.01	4.26 120.0 0.0055	1T 26.334 0.0 0.0	50.500 26.334 76.834	43.678 21.872 0.419		Vel = 3.24		
S to T	0.0 144.01	4.26 120.0 0.0055	1E 13.167 1T 26.334 0.0	7.625 39.501 47.126	65.969 0.0 0.257		Vel = 3.24		
T to U	0.0 144.01	4.26 120.0 0.0054	1E 13.167 1T 26.334 0.0	38.000 39.501 77.501	66.226 0.0 0.422		Vel = 3.24		
U to RT	0.0 144.01	4.26 120.0 0.0055	3E 39.501 0.0 0.0	8.750 39.501 48.251	66.648 0.505 0.263		Vel = 3.24		
RT to TV	0.0 144.01	4.26 120.0 0.0058	1Fsp 0.0 0.0 0.0	2.917 0.0 2.917	67.416 4.263 0.017		* Fixed loss = 3 Vel = 3.24		
TV to RB	0.0 144.01	4.26 120.0 0.0051	1Zac 0.0 0.0 0.0	3.333 0.0 3.333	71.696 3.708 0.017		* Fixed loss = 2.264 Vel = 3.24		
RB to X1	0.0 144.01	4.1 140.0 0.0049	1E 14.534 1G 2.907 1T 29.067	50.000 46.508 96.508	75.421 0.0 0.477		Vel = 3.50		
X1 to X2	100.00 244.01	12.34 140.0 0.0001	1E 42.195 2T 187.534 0.0	350.000 229.729 579.729	75.898 0.0 0.035		Qa = 100 Vel = 0.65		
X2 to X3	0.0 244.01	11.938 120.0 0.0001	1T 60.0 0.0 0.0	500.000 60.000 560.000	75.933 -6.605 0.054		Vel = 0.70		
X3 to TEST	0.0 244.01	10.02 120.0 0.0002	0.0 0.0 0.0	650.000 0.0 650.000	69.382 0.0 0.146		Vel = 0.99		
	0.0 244.01				69.528		K Factor = 29.26		

Water Supply Curve (C)

Sprinkler Systems Inc.
NORMAN HANSON DETROY

Page 7
Date 5-7-2013

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 88
C2 - Residual Flow : 1758

Demand:
D1 - Elevation : 18.479
D2 - System Flow : 144.014
D2 - System Pressure : 69.528
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 244.014
Safety Margin : 20.420

