Location of Construction:	Owner:		Phone:	Permit No: 9 51326
Owner Address:	Leasee/Buyer's Name:	Phone:	BusinessName:	DEDMIT ICCLIED
Contractor Name: The Pochebit Co., Inc. Address: 171 Werren Ave Ptld, ME 04103 797-3369				Permit Issued:
Past Use:	Proposed Use:	\$1,078,000.0		
Bank/Offices	Sane	FIRE DEPT. Signature:	Approved INSPECTION Use Group 8 30 C+ 93 Signature:	Type: CBL: 032-1-036
Proposed Project Description:			CTIVITIES DISTRICT (Zoning Approval:
Interior Renovations 3rd, 4th & 6th Floors		Action:	Approved Approved with Conditions: Denied	Special Zone or Reviews: Shoreland Wetland Flood Zone
		Signature:	Date:	☐ Subdivision
Permit Taken By: Bary Greatk	Date Applied For:	8 Dacember 1996		☐ Site Plan maj ☐ minor ☐ mm ☐
 Building permits do not include plumbing, so Building permits are void if work is not starte tion may invalidate a building permit and sto 	d within six (6) months of the date of op all work		PERMIT ICO	☐ Miscellaneous ☐ Conditional Use ☐ Interpretation ☐ Approved ☐ Denied Historic Preservation ☐ Not in District or Landmark
			PERMIT ISSU WITH LETTE	Does Not Require Review Requires Review Action:
I hereby certify that I am the owner of record of the authorized by the owner to make this application if a permit for work described in the application is areas covered by such permit at any reasonable here.	as his authorized agent and I agree to issued, I certify that the code official our to enforce the provisions of the code of t	s authorized representativode(s) applicable to such	laws of this jurisdiction. In the shall have the authority to permit	addition, Denied
	ADDRESS.	18 December 1	A Company of the Comp	
SIGNATURE OF APPLICANT SCOTE VOLEN	ADDRESS:	DATE:	PHONE:	



Planning and Urban Development Joseph E. Gray Jr. Director

CITY OF PORTLAND

December 21, 1995

The Pochebit Company, Incorporated 171 Warren Avenue Portland, Maine 04103

RE: 1 Canal Plaza
3rd, 4th and 6th Floors

Dear Sir,

Your application to make interior renovations has been reviewed and a permit is herewith issued subject to the requirements listed below. This permit does not excuse the applicant from meeting applicable State and Federal laws.

No Certificate of Occupancy will be issued until all requirements of this letter are met.

Building and Fire Code Requirements

- 1. The sprinkler system shall be maintained to NFPA 13 Standards.
- 2. The fire alarm system shall be maintained to NFPA 72 Standards.
- 3. Exit signs- each door to an enclosed exit stairway shall be equipped with tactile signage reading "EXIT" and shall be installed on the side of the door from which egress is to be made. Stairway floor number signs a sign shall be provided at each floor landing in all interior exit stairways connecting more than three stories designating the floor level above and below the level of exit discharge. The identification of the stairway and the availability of roof access from that stairway.
- 4. A portable fire extinguisher shall be located as NFPA 10. They shall bear the label of an approved agency and be of an approved type.
- 5. Safety glazing shall be used in areas of specific hazardous location as per Section 2405.0 of the City's Building Code.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

sipperely,

P. Samuel Hoffses

Chief, Code Enforcement Division

cc: Lt. McDougall, PFD