



**MECHANICAL NOTES:**  
1. SEE HEAT PUMP SCHEDULE FOR INDIVIDUAL HP PIPE SIZES.  
2. UNLESS NOTED OTHERWISE, LWS/R RISERS SERVING 2 HEAT PUMPS PER FLOOR SHALL BE 2".  
3. UNLESS NOTED OTHERWISE, LWS/R RISERS SERVING 1 HEAT PUMP PER FLOOR SHALL BE 1-1/4".

1 Third Floor HVAC Plan  
1/4" = 1'-0"

Mark	Date	Description
		ISSUED FOR CONSTRUCTION 03-01-2013

Drawing Title  
**Third Floor HVAC  
Plan-Part A**

Scale: 1/4" = 1'-0"

Drawing Number  
**M10.3A**