



① Fourth Floor HVAC Plan-Part A
1/4" = 1'-0"

MECHANICAL NOTES:
1. SEE HEAT PUMP SCHEDULE FOR INDIVIDUAL HP PIPE SIZES.
2. UNLESS NOTED OTHERWISE, LWS/R RISERS SERVING 2 HEAT PUMPS PER FLOOR SHALL BE 2".
3. UNLESS NOTED OTHERWISE, LWS/R RISERS SERVING 1 HEAT PUMP PER FLOOR SHALL BE 1-1/4".

Mark	Date	Description
		ISSUED FOR CONSTRUCTION
		03-01-2013

Drawing Title
**Fourth Floor HVAC
Plan-Part A**

Scale: 1/4" = 1'-0"

Drawing Number

M10.4A