Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/04/16

**Building Inspections - Fore St Parking Garage - Facade Repairs Revised Drawings Permit #201600428**

**From:** Joshua Martin-McNaughton <JMartinMcNaughton@beckerstructural.com>
**To:** "buildinginspections@portlandmaine.gov" <buildinginspections@portlandmai...
**Date:** 3/9/2016 8:33 AM
**Subject:** Fore St Parking Garage - Facade Repairs Revised Drawings Permit #201600428
**Attachments:** D2 Demolition Sections and Details.pdf; S0 General Notes.pdf; S1 Framing Plans and Elevation.pdf; S2 Sections and Details.pdf; D1 Demolition Plan and Elevation.pdf

Please see the attached revised drawings for the Fore St Parking Garage Façade Repair project permit #201600428. Revisions include increased bumper depth and height to limit vehicle headlight illumination out of the garage and revised metal mesh panel steel supports.

Contact me with any questions.
Josh

Josh Martin-McNaughton, P.E.
Project Engineer
**Becker Structural Engineers, Inc.**
direct 207.879.1838 x138
www.beckerstructural.com