

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT

**This is to certify that**

COW PLAZA GARAGE LLC

**Located at**

425 FORE ST

**PERMIT ID:** 2016-02660

**ISSUE DATE:** 12/09/2016

**CBL:** 032 I041001

has permission to **For the installation of a 14' hood system with make-up air.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Michael White*

**Fire Official**

*/s/ Michael Russell, MS, Director*

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*

*Building Inspections*

*Fire Department*

**PERMIT ID:** 2016-02660

**Located at:** 425 FORE ST

**CBL:** 032 I041001

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

### **REQUIRED INSPECTIONS:**

Final - Commercial

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2016-02660	<b>Date Applied For:</b> 10/11/2016	<b>CBL:</b> 032 I041001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Same: Parking garage, restaurants, retail, and bank ATM.		<b>Proposed Project Description:</b> For the installation of a 14' hood system with make-up air.		
<b>Dept:</b> Zoning		<b>Status:</b> Approved	<b>Reviewer:</b> Jennifer Thompson	<b>Approval Date:</b> 12/09/2016
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>				
<b>Dept:</b> Fire		<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Michael White	<b>Approval Date:</b> 10/17/2016
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>		<ol style="list-style-type: none"> <li>1) Installation shall comply with NFPA 90A, Standard for the Installation of Air-Conditioning and Ventilating Systems; NFPA 90B, Standard for the Installation of Warm Air Heating and Air Conditioning Systems; NFPA 91, Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Noncombustible Particulate Solids; NFPA 31, Standard for the Installation of Oil Burning Equipment; NFPA 211 Standard for Chimneys, Fireplaces, Vents, and Solid Fuel Burning Appliances; NFPA 54, National Fuel Gas Code; NFPA 70 National Electrical Code; and all manufacturer's published recommendations.</li> <li>2) All construction shall comply with 2009 NFPA 101, Chapter 9, Building Service and Fire Protection Equipment.</li> <li>3) If applicable, all outstanding code violations shall be corrected prior to final inspection.</li> <li>4) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).</li> <li>5) All construction shall comply with City Code, Chapter 10.</li> </ol>		