



- NOTES
- FIELD PIPE DROPS AS SHOWN
 - SLEEVING, ELBOWS, TEES, AND NOZZLES SUPPLIED BY GAS
 - RELOCATE NOZZLES IF FLOW PATTERN IS BLOCKED BY SLEEVING, SALAMANDERS, ETC.
 - MAXIMUM 9' ELBOWS IN SUPPLY LINE
 - MINIMUM 7/2" INCHES OF AGENT LINE FROM TANK TO FIRST NOZZLE
 - IF APPLICABLE, PRE-PIPED CHAMBERLAIN DROPS ARE SHIPPED LOOSE.
 - FACTORY PIPING EXTENDS A MAXIMUM OF 6" ABOVE THE TOP OF THE HOOD.
 - APPLIANCE DIMENSIONS LISTED REPRESENT THE COOKING SURFACE SIZE, NOT THE OVERALL APPLIANCE SIZE
 - THIS FIRE SYSTEM COMPLIES WITH U.L. 300 REQUIREMENTS
- Job #: 1247884
 Drawn By: Fire Guys - Medford, MA
 Down Size: ANSUL-3.0/3.0, Total FP required: 20
 Hood # 1 Size: 10' x 17' x 33" Wide x 47" High
 Hood # 2 Size: 10' x 17' x 33" Wide x 47" High
 Hood # 3 Size: 10' x 17' x 33" Wide x 47" High
 Hood # 4 Size: 10' x 17' x 33" Wide x 47" High
- LEGEND - FIRE CABINET ANSUL SYSTEM**
- 1A 15 GALLON TANK
 - 1B 3 GALLON TANK
 - 1C DEM AUTOMAN RELEASE
 - 2 DEM REGULATED RELEASE
 - 3 DEM REGULATED ACTUATOR
 - 4 ANSULX LIQUID AGENT (3 GAL.)
 - 5 ANSULX LIQUID AGENT (1.5 GAL.)
 - 6 CARTRIDGE (101-20)
 - 7 CARTRIDGE (101-10)
 - 8 CARTRIDGE (101-30)
 - 9A CARTRIDGE (101-30)
 - 9B CARTRIDGE (101-30)
 - 10 TEST TANK CARTRIDGE
 - 11 DOUBLE MICROSWITCH
 - 12 HOSE ASSEMBLY
 - 1100 DUCT NOZZLE (430913)
 - 11V NOZZLE ASSEMBLY (419337)
 - 11F NOZZLE ASSEMBLY (419336)
 - 11N NOZZLE ASSEMBLY (419335)
 - 11/2N NOZZLE ASSEMBLY (419334)
 - 3N NOZZLE ASSEMBLY (419333)
 - 24S NOZZLE ASSEMBLY (419340)
 - 240 NOZZLE ASSEMBLY (419339)
 - 2190 NOZZLE ASSEMBLY (419342)
 - 260 NOZZLE ASSEMBLY (419341)
 - 280 DETECTOR BRACKET
 - 29 LOW TEMP FUSIBLE LINK
 - 30 HIGH TEMP FUSIBLE LINK
 - MGV MECHANICAL GAS VALVE
 - EGV ELECTRICAL GAS VALVE
 - 34 REMOTE MANUAL PULL STATION
 - S SVAVE ADAPTER