

EXHAUST FAN INFORMATION - Job#2692009

FAN UNIT NO.	TAG	FAN UNIT MODEL #	CFM	ESP.	RPM	H.P.	B.H.P.	Ø	VOLT	FLA	DISCHARGE VELOCITY	WEIGHT (LBS.)	SONES
1		CASRE20BD	2437	3.000	1532	5.000	3.2370	1	230	24.6	1132 FPM	482	27

MUA FAN INFORMATION - Job#2692009

FAN UNIT NO.	TAG	FAN UNIT MODEL #	BLOWER	HOUSING	CFM	ESP.	RPM	H.P.	B.H.P.	Ø	VOLT	FLA	WEIGHT (LBS.)	SONES
2		INLINE1-G10	G10	INLINE.1L	1950	1.000	1135	2.000	0.9070	1	230	9.3	243	13.6

FAN OPTIONS

FAN UNIT NO.	TAG	OPTION (Qty. - Descr.)
1		1 - Full Crating For Exhaust Fans
		1 - Utility Set Grease Cup
		1 - 3 Year Extended Motor Warranty
		1 - Extra Set of Belts
		1 - Fan Base Ceramic Seal - For Grease Ducts
		1 - RE20 - Discharge Extension Assembly With Hardware.
2		1 - Full Crating For Untempered Fans
		1 - 3 Year Extended Motor Warranty
		1 - Extra Set of Belts
		1 - INLINE1 Indoor Hanging Option - Includes 2 HSA125 Hanging Spring Isolators per Uni-Strut

FAN ACCESSORIES

FAN UNIT NO.	TAG	EXHAUST			SUPPLY			
		GREASE CUP	GRAVITY DAMPER	WALL MOUNT	SIDE DISCHARGE	GRAVITY DAMPER	MOTORIZED DAMPER	WALL MOUNT
1		YES						
2					YES			

CUSTOMER APPROVAL TO MANUFACTURE:

Approved as Noted

Approved with NO Exception Taken

Revise and Resubmit

SIGNATURE _____

Your Title _____ Date _____



JOB Old Port Lobster Company r1	
LOCATION SCARBOROUGH, ME,	
DATE 7/11/2016	JOB # 2692009
DWG # 4	DRAWN BY BFC-21
REV.	SCALE 3/8" = 1'-0"