



**MECHANICAL NOTES:**  
 1. SEE HEAT PUMP SCHEDULE FOR INDIVIDUAL HP PIPE SIZES.  
 2. UNLESS NOTED OTHERWISE, LWS/R RISERS SERVING 2 HEAT PUMPS PER FLOOR SHALL BE 2".  
 3. UNLESS NOTED OTHERWISE, LWS/R RISERS SERVING 1 HEAT PUMP PER FLOOR SHALL BE 1-1/4".

1 Fifth Floor HVAC Plan-Part A  
 1/4" = 1'-0"

Mark Date Description  
 Project Status  
**ISSUED FOR  
 CONSTRUCTION**  
 03-01-2013

Drawing Title  
**Fifth Floor HVAC  
 Plan-Part A**

Scale: 1/4" = 1'-0"

Drawing Number  
**M10.5A**