



MECHANICAL NOTES:
 1. SEE HEAT PUMP SCHEDULE FOR INDIVIDUAL HP PIPE SIZES.
 2. UNLESS NOTED OTHERWISE, LWS/R RISERS SERVING 2 HEAT PUMPS PER FLOOR SHALL BE 2".
 3. UNLESS NOTED OTHERWISE, LWS/R RISERS SERVING 1 HEAT PUMP PER FLOOR SHALL BE 1-1/4".
 4. ALL HEAT PUMPS THIS FLOOR SHALL HAVE 3-WAY CONTROL VALVES.

1 Seventh Floor HVAC Mechanical Plan
1/4" = 1'-0"

Mark	Date	Description

Project Status

**ISSUED FOR
CONSTRUCTION**
03-01-2013

Drawing Title

**Seventh Floor
HVAC Plan-Part A**

Scale: 1/4" = 1'-0"

Drawing Number

M10.7A