PACKAGED ENERGY RECOVERY VENTILATOR PERFORMANCE SCHEDULE

TAG	AIR STREAM	DUCT CONNECTIONS		UNIT AIRFLOW					ENERGY RECOVERY WHEEL - WINTER					ENERGY RECOVERY WHEEL - SUMMER					INDIRECT GAS HEATING			DX COOLING			ELECTRICAL DATA				BASIS OF DESIGN + GREENHECK	
		ENTERING	LEAVING	CFM	E.S.P. (IN.W.C.)	T.S.P. (IN.W.C.)	H.P.	B.H.P.	E.D.B. (°F)	E.W.B. (°F)	L.D.B. (°F)	L.W.B. (°F)	EFF. (%)	E.D.B. (°F)	E.W.B. (°F)	L.D.B. (°F)	L.W.B. (°F)	EFF. (%)	FURNACE SIZE	OUTPUT (MBH)	L.A.T. (°F)	TOTAL (MBH)	L.A.T. (°F)	TONNAGE	PREHEAT KW	M.C.A.	BREAKER	VOLTAGE	WEIGHT (LBS)	MODEL
ERV-1	SUPPLY	HOOD	BOTTOM	2500	1.0	1.6	2.0	1.6	-5.0	-6.2	35.8	43.8	78.9	87.0	74.0	77.9	66.4	78.9	100.0	69.0	70.0	100.5	53.0	4.0	8.2	36.7	70.0	208/3/60	3000	ERCH-45L-15
	EXHAUST	BOTTOM	HOOD	2500	1.0	1.2	2.0	1.4	72.0	-	11.2	10.3	78.9	75.0	-	-	-	78.9												
ERV-2	SUPPLY	HOOD	BOTTOM	3500	1.0	2.1	3.0	2.7	-5.0	-6.2	49.2	59.8	78.4	87.0	74.0	78.6	67.3	78.4	100.0	79.0	70.0	164.4	53.0	6.25	8.2	85.4	100.0	208/3/60	3750	ERCH-45H-15
	EXHAUST	BOTTOM	HOOD	3500	1.0	1.3	3.0	2.1	72.0	-	17.8	16.2	78.4	75.0	-	83.4	71.3	78.4												
ERV-3	SUPPLY	HOOD	BOTTOM	3250	1.0	2.1	3.0	2.3	-5.0	-6.2	50.2	60.5	71.7	87.0	74.0	78.4	67.1	71.7	100.0	79.0	70.0	164.4	53.0	6.25	8.2	89.5	100.0	208/3/60	3750	ERCH-45H-15
	EXHAUST	BOTTOM	HOOD	3250	1.0	1.3	3.0	2.1	72.0	-	16.8	15.3	71.7	75.0	-	83.6	71.3	71.7												

WATER SOURCE HEAT PUMP PERFORMANCE SCHEDULE

TAGS (HP-*)	ARRANG.	NOMINAL SIZE (TONS)	UNIT AIRFLOW				WATER COIL			HEAT PUMP - HEATING					HEAT PUMP - COOLING							ELECTRICAL DATA			BASIS OF DESIGN - MCQUAY		
			S.A. CFM	E.S.P. (IN.W.C.)	FAN H.P.	ECM	FLOW (GPM)	W.P.D. (FT.W.G.)	VALVE	E.D.B. (°F)	L.D.B. (°F)	E.W.T. (°F)	L.W.T. (°F)	CAP. (MBH)	COP	E.D.B. (°F)	E.W.B. (°F)	E.W.T. (°F)	L.W.T. (°F)	TOT. (MBH)	SENS. (MBH)	EER	M.C.A.	BREAKER	VOLTAGE	WEIGHT (LBS)	REMARKS	MODEL
201,207,2014-216,218,236,237, 349,3212,3214-336,338-521, 326-329,401,402,404-416, 418-421,426-429,5401,5612, 5614-5618,5621,5626-5629, 601,6201,6204-6216,618-621, 626-629,1103,1106,1107	VERTICAL STACK	0.75	375	0.11	0.06	N	1.0	3.2	V-1 V-11	70.0	56.4	120.0	60.6	10.6	3.23	80.0	67.0	88.0	93.8	9.3	8.3	13.6	5.1	15.0	208/1/60	161	1/2"LWS/R, 1"C RETURN AIR GRILLE / ACCESS DOOR	UVHC1009
200,300,400,500,600, 107,1014,1215,1218,1219, 1119,1111	VERTICAL STACK	2.0	750	0.31	0.12	Y	5.0	7.4	V-2 V-12	70.0	107.1	120.0	62.2	29.9	4.93	80.0	67.0	88.0	97.9	24.4	18.8	14.9	19.7	30.0	208/1/60	313	3/4"LWS/R, 1"C RETURN AIR GRILLE / ACCESS DOOR	UVHC1024
203,2123,2131,2313,303, 4603,5613,6103,1101	VERTICAL STACK	2.5	1050	0.61	0.20	Y	6.0	3.7	V-3 V-13	70.0	101.6	120.0	59.3	38.7	4.81	80.0	67.0	88.0	100.4	28.6	24.2	14.6	21.9	35.0	208/1/60	321	3/4"LWS/R, 1"C RETURN AIR GRILLE / ACCESS DOOR	UVHC1030
116,1112,1215	CONSOLE	1.5	392	0.00	0.05	N	2.5	3.9	V-1	70.0	119.1	120.0	56.4	20.7	4.53	80.0	67.0	88.0	104.7	16.6	11.0	13.4	9.5	15.0	208/1/60	171	3/4"LWS/R, 3/4"C	WHC1018
132	HORIZ.	0.75	300	0.50	0.125	N	2.0	5.8	V-1	70.0	107.5	120.0	60.6	12.1	4.37	80.0	67.0	88.0	98.9	8.2	5.5	10.9	5.8	15.0	208/1/60	99	1/2"LWS/R, 3/4"C	WCCH4009
108	HORIZ.	1.5	630	0.75	0.33	Y	4.0	4.5	V-2	70.0	106.1	120.0	60.4	24.5	4.6	80.0	67.0	88.0	100.8	20.2	15.4	17.8	10.5	15.0	208/1/60	155	1/2"LWS/R, 3/4"C	WCCH4019
1241,133	HORIZ.	2.0	800	0.45	0.33	Y	5.0	7.1	V-2	70.0	103.9	120.0	60.3	29.2	4.6	80.0	67.0	88.0	99.9	23.4	16.8	17.6	12.1	15.0	208/1/60	195	1/2"LWS/R, 3/4"C	WCCH4024
101	HORIZ.	3.0	1200	0.5	0.5	Y	8.0	6.4	V-4	70.0	102.9	120.0	61.7	42.5	4.6	80.0	67.0	88.0	99.1	35.9	25.8	14.5	25.1	40.0	208/1/60	223	3/4"LWS/R, 3/4"C	WCCH5036
113A,113B	HORIZ.	6.0	2330	0.35	1.0	Y	15.0	17.1	V-5	70.0	105.0	120.0	61.1	87.9	4.1	80.0	67.0	88.0	100.0	69.8	50.6	12.0	40.3	65.0	208/3/60	332	3/4"LWS/R, 3/4"C	WCCH4010

PROVIDE WITH CONDENSATE PUMPS WHERE REQUIRED.

MECHANICAL AND PLUMBING SYMBOLS AND ABBREVIATIONS LEGEND

NOTE - USE SYMBOLS AND ABBREVIATIONS AS APPLICABLE FOR THIS MECHANICAL DRAWING SET. SOME SYMBOLS AND ABBREVIATIONS IN THIS LEGEND MAY NOT APPLY.

SYMBOL	DESCRIPTION
CA	COMPRESSED AIR PIPING (CA)
C	CONDENSATE DRAIN PIPING (C)
CTR	COOLING TOWER RETURN PIPING (CTR)
CTS	COOLING TOWER SUPPLY PIPING (CTS)
CWR	CHILLED WATER RETURN PIPING (CWR)
CWS	CHILLED WATER SUPPLY PIPING (CWS)
FOR	FUEL OIL RETURN PIPING (FOR)
FOS	FUEL OIL SUPPLY PIPING (FOS)
G	GAS PIPING (G)
HWR	HOT WATER RETURN PIPING (HWR)
HWS	HOT WATER SUPPLY PIPING (HWS)
RL	REFRIGERANT LIQUID PIPING (RL)
RG	REFRIGERANT GAS PIPING (RGS)
SAN	SANITARY PIPING BELOW FLOOR (SAN)
	SANITARY PIPING ABOVE FLOOR (SAN)
	SANITARY VENT PIPING
RWL	RAINWATER LEADER ABOVE SLAB (RWL)
CW	COLD WATER PIPING (CW)
HW	HOT WATER PIPING (HW)
RHW	RECIRCULATED HOT WATER PIPING (RHW)
	PIPE CAP
	DIRECTION OF FLUID FLOW
	ELBOW UP
	ELBOW DOWN
	PIPE TEE UP
	PIPE TEE DOWN
	PIPE REDUCER
	PIPE WITH GUIDE
	PIPE WITH ANCHOR
	BUTTERFLY VALVE
	OS & Y GATE VALVE

SYMBOL	DESCRIPTION
	BACKFLOW PREVENTER (BFP)
	CHECK VALVE
	BALANCING VALVE (ADJUSTABLE)
	AUTOMATIC FLOW CONTROL VALVE
	RELIEF VALVE (RV)
	BALL VALVE
	BALL VALVE
	3/4" BALL VALVE WITH 3/4" HOSE END
	GATE VALVE
	PRESSEURE REDUCING VALVE
	FUSIBLE VALVE
	STRAINER W/BLOWDOWN BALL VALVE
	2-WAY CONTROL VALVE
	SOLENOID VALVE
	3-WAY CONTROL VALVE
	3-WAY CONTROL VALVE (TOP VIEW)
	4-WAY CONTROL VALVE (TOP VIEW)
	2 BUTTERFLY VALVES W/SINGLE ACTUATOR
	BUTTERFLY VALVE W/ACTUATOR
	TRIPLE-DUTY VALVE
	UNION
	PIPE FLANGE
	PUMP WITH FLANGES
	BASE MOUNTED PUMP
	CARTRIDGE TYPE INLINE PUMP
	VERTICAL INLINE PUMP
FC	FLEXIBLE PIPE CONNECTION (FC)
	PITCH DOWN
	FIETCOCK
	FLOW METER

SYMBOL	DESCRIPTION
	PRESSURE GAGE WITH GAGE COCK
	THERMOMETER IN WELL
	WATER FLOW SWITCH
	PRESSURE SWITCH OR SENSOR
	IMMERSION TEMPERATURE SENSOR
	DUCT MOUNTED SMOKE DETECTOR
	ROOM TEMPERATURE SENSOR
	THERMOSTAT OR SENSOR ON WALL
	TSTAT OR SENSOR W/ TAMPERPROOF GUARD
	MANUAL AIR VENT
	NOTE TAG (NUMBER)
12"x6"	AIR DEVICE TAG (LETTER) WITH CFM
	ROOM NUMBER
	TURNING VANES
	DUCT W/MANUAL DAMPER
	DUCT W/FLEXIBLE CONNECTION (FC)
	LAGGED DUCT
	DUCT W/ACOUSTIC LINING
	DUCT W/SQUARE-TO-ROUND TRANSITION
	FLEXIBLE DUCT
MOD	MOTOR OPERATED DAMPER
	AIRFLOW OUT
	AIRFLOW IN
	DIAMETER OR FLAT OVAL
	FIRE DAMPER
	ROUND OR FLAT OVAL DUCT DOWN
	ROUND OR FLAT OVAL DUCT UP
	SUPPLY DIFFUSER
	RETURN GRILLE
	STEAM TRAP
	WATER HAMMER ARRESTOR
	HUMIDISTAT

ABBREVIATION	DESCRIPTION
AAV	AUTOMATIC AIR VENT
AD	ACCESS DOOR
AFF	ABOVE FINISHED FLOOR
AHU-*	AIR HANDLING UNIT TAG
AMS	AIRFLOW MONITORING STATION
AMPS	AMPERES
AP	ACCESS PANEL
APD	AIR PRESSURE DROP
AS-*	AIR SEPARATOR TAG
ATC	AUTOMATIC TEMPERATURE CONTROL
B-*	BOILER TAG
BD-*	BYPASS DAMPER TAG
BFP-*	BACKFLOW PREVENTER TAG
BHP	BRAKE HORSEPOWER
BTUH	BRITISH THERMAL UNITS PER HOUR
CBD	COUNTER BALANCED DAMPER
CC-*	COOLING COIL TAG
CFM	CUBIC FEET PER MINUTE
CHLR-*	CHILLER TAG
CO	CLEANOUT
CONV-*	CONVECTOR TAG
CUH-*	CABINET UNIT HEATER TAG
CP-*	CIRCULATING PUMP TAG
CT-*	COOLING TOWER TAG
Cv	VALVE COEFFICIENT
CW	COLD WATER
CHWS/R	CHILLED WATER SUPPLY AND RETURN
DB	DRY BULB
dB re	DECIBELS RELATIVE TO
DC	DOUBLE CHECK
DCA	DOUBLE CHECK ATMOSPHERIC
DEG F	DEGREES FAHRENHEIT
DIA	DIAMETER
DIW	DOWN IN WALL
DN	DOWN
EA	EXHAUST AIR
EAT	ENTERING AIR TEMPERATURE

ABBREVIATION	DESCRIPTION
EDB	ENTERING DRY BULB
EDC-*	ELECTRIC DUCT COIL TAG
EER	ENERGY EFFICIENCY RATIO
EF-*	EXHAUST FAN TAG
EFF	EFFICIENCY
EG-*	EXHAUST GRILLE TAG
ER-*	EXHAUST REGISTER TAG
ESP	EXTERNAL STATIC PRESSURE
ET-*	EXPANSION TANK TAG
EWB	ENTERING WET BULB
EWH-*	ELECTRIC WATER HEATER TAG
EWT	ENTERING WATER TEMPERATURE
EXG	EXISTING
EXH	EXHAUST
FC	FLEXIBLE CONNECTION
FCO	FLOOR CLEANOUT
FD	FIRE DAMPER
FD-*	FLOOR DRAIN TAG
FLA	FULL LOAD AMPS
FOR	FUEL OIL RETURN
FOS	FUEL OIL SUPPLY
FPHB	FROST PROOF HOSE BIBB
FPM	FEET PER MINUTE
FS-*	FLOOR SINK TAG
FT	FEET
FTR-*	FINTUBE RADIATION TAG
GA	GAGE
GAL	GALLONS
GFUH-*	GAS FIRED WATER HEATER TAG
GPH	GALLONS PER HOUR
GPM	GALLONS PER MINUTE
GUH-*	GAS UNIT HEATER TAG
HC-*	HEATING COIL TAG
HP	HORSEPOWER
HRV-*	HEAT RECOVERY VENTILATOR TAG
HW	HOT WATER
HWS/R	HOT WATER SUPPLY AND RETURN

ABBREVIATION	DESCRIPTION
I=B-/R	INSTITUTE OF BOILER AND RADIATOR MANUFACTURERS
IWH-*	INDIRECT FIRED WATER HEATER TAG
IN.	INCHES
IV-*	INTAKE VENT TAG
L-*	LOUVER TAG
LAT	LEAVING AIR TEMPERATURE
LB	POUNDS
LD-*	LINEAR DIFFUSER TAG
LTHW/R	LOW TEMPERATURE HOT WATER
LRA	LOCKED ROTOR AMPS
LWCO	LOW WATER CUTOUT
LWT	LEAVING WATER TEMPERATURE
MAX.	MAXIMUM
MBH	THOUSANDS OF BTU PER HOUR
MCA	MINIMUM CIRCUIT AMPACITY
MIN	MINIMUM
NC	NOISE CRITERION
NIC	NOT IN CONTRACT
NTS	NOT TO SCALE
OA	OUTSIDE AIR
OBD	OPPOSED BLADE DAMPER
O.D.	OUTSIDE DIAMETER
OED	OPEN ENDED DUCT
OFUH-*	OIL FIRED WATER HEATER TAG
OPD	OVERCURRENT PROTECTIVE DEVICE
P-*	PLUMBING FIXTURE TAG
PENETN	PENETRATION
PF-*	PADDLE FAN TAG
PSIA	POUNDS PER SQUARE INCH ABSOLUTE
PSIG	POUNDS PER SQUARE INCH GAGE
PVC	POLYVINYL CHLORIDE (PIPE)
RA	RETURN AIR
RD	ROOF DRAIN
RDE	RECOMMENDED DUAL ELEMENT FUSE AMPS
RFH-*	RADIANT FLOOR MANIFOLD TAG
RG-*	RETURN GRILLE TAG
RHW	RECIRCULATED HOT WATER

ABBREVIATION	DESCRIPTION
RLA	RUNNING LOAD AMPS
RPM	REVOLUTIONS PER MINUTE
RPS	REVOLUTIONS PER SECOND
RPZ	REDUCED PRESSURE ZONE
RR-*	RETURN REGISTER TAG
RTU	ROOM TEMPERATURE SENSOR
RV	RELIEF VALVE
RWL	RAINWATER LEADER
SA	SUPPLY AIR
SAN	SANITARY (DRAIN & WASTE)
SD	SMOKE DAMPER
SEER	SEASONAL ENERGY EFFICIENCY RATIO
SF	SUPPLY FAN
SG-*	SUPPLY GRILLE TAG
SP	STATIC PRESSURE
SP-*	SUMP PUMP TAG
SR-*	SUPPLY REGISTER TAG
SQFT	SQUARE FEET
ΔT	TEMPERATURE DIFFERENTIAL
TEMP.	TEMPERATURE
TCP	TEMPERATURE CONTROL PANEL
TMV-*	THERMOSTATIC MIXING VALVE TAG
TSP	TOTAL STATIC PRESSURE
TYP	TYPICAL
UH-*	UNIT HEATER TAG
VAV-*	VARIABLE AIR VOLUME BOX TAG
VB	VACUUM BREAKER
VFD	VARIABLE FREQUENCY INVERTER DRIVE
VTR	VENT THRU ROOF
V/PH/HZ	VOLTS/PHASES/HERTZ
WB	WET BULB
WCO	WALL CLEANOUT
WG	WATER GAGE
WPD	WATER PRESSURE DROP
WSA	WIRE SIZING AMPS
WTD	WATER TEMPERATURE DROP
W/	WITH
ZD-*	ZONE DAMPER TAG

CANAL 5 STUDIO
Architecture / Planning / Interior Design
207 553 2115
One Canal Plaza, Suite 888
Portland, Maine 04101
canal5studio.com

Project Title

HYATT PLACE PORTLAND - OLD PORT

433 FORE STREET, PORTLAND, ME

C5 Project No. 12013

BENNETT ENGINEERING
MECHANICAL • ELECTRICAL
(207) 865-9475

STATE OF MAINE — STEPHEN P. DOEL — No. 12007 — REGISTERED PROFESSIONAL ENGINEER

Mark	Date	Description

Project Status

ISSUED FOR CONSTRUCTION

03-01-2013

Drawing Title

Mechanical Legend and Schedules

Scale:

Drawing Number

M30.1