



Portland Fire Department

386 FORE STREET LLC
PO BOX 7225
PORTLAND, ME 04112

CERTIFIED MAIL

RE: 384 FORE ST
PORTLAND, ME 04101

032 J001001

384 FORE ST Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 6/1/2018 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 8/15/2018 10:00:00AM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan
Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-9.1.2; NFPA 70	All electrical equipment must comply with the National Electric Code.	several extention cords used as permanet wiring. 384 Fore St	6/1/2018
