

NOTIFICATION APPLIANCE CIRCUIT VOLTAGE DROPS
 UNITED STATES COAST GUARD
 2 MONUMENT SQUARE
 PORTLAND, ME

PANEL	CIRCUIT	WIRE GAUGE	LENGTH	CURRENT DRAW	VOLTAGE DROP	VOLTAGE LOSS	END VOLTAGE
FCPS	NAC 1	#12AWG	488 FT	2.104A	3.26VDC	13.58%	20.74VDC
FCPS	NAC 2	UNUSED					
FCPS	NAC 3	#16AWG	346 FT	0.385A	1.07VDC	4.46%	22.93VDC
FCPS	NAC 4	UNUSED					