


- NOTES:**
- REFER TO DRAWING FP-0 FOR SYMBOLS AND GENERAL PROJECT REQUIREMENTS.
 - REFER TO DRAWING FP-1 FOR FIRE PROTECTION SPECIFICATIONS AND SCHEDULES.
 - REMOVE EXISTING FIRE SPRINKLER SYSTEM TO THE EXTENT INDICATED. PERFORM NECESSARY PERMANENT OR TEMPORARY TIE-INS TO MAINTAIN OPERATION OF PORTIONS OF EXISTING FIRE SPRINKLER SYSTEM TO REMAIN.
 - CONFIRM EXACT LOCATIONS OF SPRINKLERS, PIPING, FIRE HOSE VALVES AND OTHER EQUIPMENT IN FIELD.
 - COORDINATE SYSTEM IMPAIRMENTS AND TEMPORARY FIRE PROTECTION PROVISIONS WITH THE OWNER AND LOCAL AUTHORITIES.
 - REMOVAL SHALL BE PERFORMED BY SPRINKLER FITTERS LICENSED IN MAINE.
 - REFER TO ARCHITECTURAL AND STRUCTURAL SERIES DRAWINGS FOR STRUCTURAL FRAMING PLANS, DETAILED REFLECTED CEILING PLANS, ELEVATIONS, AND SECTIONS.
 - MAINTAIN SPRINKLER CLEARANCE FROM STRUCTURAL MEMBERS IN ACCORDANCE WITH THE SPECIFIC REQUIREMENTS OF NFPA 13.
 - MAINTAIN SPRINKLER CLEARANCE FROM CEILING AND FLOOR MOUNTED OBSTRUCTIONS SIMILAR TO (BUT NOT LIMITED TO) SHELVING, ROOM DIVIDERS, LIGHT FIXTURES, EXIT SIGNS, SOFFITS AND CHANGES IN CEILING ELEVATION, IN ACCORDANCE WITH THE SPECIFIC REQUIREMENTS OF NFPA 13.
 - INSTALL SPRINKLERS IN CENTER OF SUSPENDED CEILING TILE, ALONG CENTER-LINE OF CEILING FEATURES AND IN-LINE WITH ADJACENT CEILING FIXTURES.
 - THROUGHOUT THE SCOPE OF WORK, INSTALL SUPPORTS ON EXISTING PIPING WHERE EXISTING SUPPORT SPACING EXCEEDS NFPA 13 REQUIREMENTS.
 - REPLACE EXISTING 1-INCH BRANCH CONNECTIONS TO MAINS WHERE CONNECTION IS MADE VIA 3/4"x1" INCREASER BY PLUGGING EXISTING 3/4" OUTLET AND CONNECTING TO MAIN WITH NEW HOLE CUT FITTING.


KEYNOTES:

◊ AREA NOT IN FIRE PROTECTION SCOPE. ALL SPRINKLER HEADS IN AREA ARE EXISTING TO REMAIN.



1 FIRE PROTECTION PLAN
1/8" = 1'-0"

Dyer Brown & Associates Inc. - ©2017 ALL RIGHTS RESERVED - PLOTTED: 03/01/2017 10:23:37 - BDA Home Loans Colocation 1 Monument Square, Portland, ME 04101. Drawing: 052 Fire Protection/052 Fire Protection/052 Fire Protection/052 Fire Protection PLAN.dwg (Rev) June 29, 2017 - 10:24am ewd/kl



REVISIONS

BANK OF AMERICA - HOME LOANS

BANK OF AMERICA
1 MONUMENT SQUARE, PORTLAND ME

TITLE
FIRE PROTECTION PLAN

DATE 06/29/17 **JOB NO.** 20170237

DRAWING NO. **FP-2**

ISSUED FOR CONSTRUCTION