Please fill out any part which applie	rtland BUILDING PERMY es to job. Proper plans must accompany fo	TAPPLICATION Fees 40.00 Zone Map # 32-k-012.
Address: 1 Monument Way Po LOCATION OF CONSTRUCTION 1 A Contractor: Cathy Alves Address: 41 Turner St.	Conument Way 2 Md / Sub.:Phone #	Date May _ 27 , 1994
# of Existing Res. Units# Building Dimensions LW # Stories:# Bedrooms Is Proposed Use: Seasonal(Proposed Use:office Past Use:office closing : of New Res. Units Total Sq. Ft Lot Size: Condominium Conversion fit_up	Street Frontage Provided:
Foundation: 1. Type of Soil: 2. Set Backs - Front 3 Footings Size: 4. Foundation Size: 5. Other Floor:	ebris being hauled away by concentrations. RearSide(s) Sills must be anchored. Size:Spacing 16" O.C.	Ceiling: 1. Ceiling Joists Size: 2. Ceiling Strapping Size 3. Type Ceilings: 4. Insulation Type 5. Ceiling Height: Roof: 1. Truss or Raftc. Size 2. Sheathing Type 3. Roof Covering Type Chimneys: Type: Number of Fire Places Heating:
6. Floor Sheathing Type:	Size:	Electrical: Service Entrance Size: Smoke Detector Required Yes No Plumbing: 1. Approval of soil test if required Yes No 2. No. of Tubs or Showers 3. No. of Flushes
9 Siding Type 10. Masonry Materials 11 Metal Materials Interior Walls: 1 Studding Size 2. Header Sizes	Weather ExposureSpacingSpan(s)	Permit Received By Jatini PER NSignature of Significant Cien Alden CONTINUED TO REVERSE SIDE
	White - Tax Assessor	Ivory Tag - CEO

Inspection Services Samuel P. Hoffses Chief



Planning and Urban Development Joseph E. Gray Jr. Director

CITY OF PORTLAND

June 1, 1994

Tom Tureen 1 Monument Way Portland, Maine 04101

> RE: 1 Monument Way Portland, Maine

Dear Sir,

Your application to do a tenant fit-up has been reviewed and a permit is herewith issued subject to the following requirements: This permit doesn't preclude the applicant from meeting applicable State and Federal laws.

No Certificate of Occupancy can be issued until all requirements of this letter are met.

1. The sprinkler shall be maintained to NFPA #13 standards.

2. The Fire Detection System shall be extended into the new proposed area.

3. Portable fire extinguishers shall be provided in accordance with NFPA #10.

If you have any questions, please give this office a call.

Suncerely

Samuel Hoffses

Chief of Inspection Services

cc: Lt. MacDougall - Fire Prevention Bureau



