

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

FINARD MURRAY W TR

Located at

1 MONUMENT SQ

PERMIT ID: 2015-01146

ISSUE DATE: 06/02/2015

CBL: 032 K012001

has permission to **Interior tenant Fit-up of office spaces including all new architectural work, new mechanical, electrical, Plumbing and Fire suppression.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Bank on 1st floor with offices above

Building Inspections

Use Group: B

Type: 1A

Business

Occupant Load = 123 each floor

NFPA 13 Sprinkler System

Floors 9 & 10

MUBEC/IBC 2009

Fire Department

PERMIT ID: 2015-01146

Located at: 1 MONUMENT SQ

CBL: 032 K012001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Above Ceiling Inspection

Final Inspection

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-01146	Date Applied For: 05/20/2015	CBL: 032 K012001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Commercial Office Floors 9 and 10, "Bank of America Offices"		Proposed Project Description: Interior tenant Fit-up of office spaces including all new architectural work, new mechanical, electrical, Plumbing and Fire suppression.		
Dept: Historic		Status: Approved w/Conditions	Reviewer: Deborah Andrews	Approval Date: 06/01/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Any exterior alteration, including sign installation, associated with new tenant fit-up, will be subject to separate Historic Preservation review.				
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 05/27/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) Separate permits shall be required for any new signage.				
3) This permit approves interior work only.				
4) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				