

GENERAL CONTRACTOR ON RECORD:

SPECIAL APPLICATIONS:
 NO. DESCRIPTION:

- LEGEND:
- IN PIPE RISER UP
 - ON PIPE RISER DOWN
 - ADJUNCT DRAIN
 - SYSTEM RISER
 - PIPE PITCH 1/4" MANS 1/2" LINES
 - 4 WAY SWAY BRACING
 - 2 WAY SWAY BRACING
 - HYDRAULIC CALC. POINT

DESIGN NOTES:
 ALL PIPING 1/2" & LARGER TO BE SCHEDULE 40
 ALL PIPING 1/2" & LARGER TO BE SCHEDULE 40
 WITH APPROPRIATE FITTING TO BE SCHEDULE 40
 WITH APPROPRIATE FITTING TO BE SCHEDULE 40
 POSITION, LOCATION, SPACING, AND USE OF SPRINKLER
 HEADS SHALL BE IN ACCORDANCE WITH NFPA 13.
 HYDRAULIC CALCULATION PROCEDURES HAVE BEEN
 USED TO DETERMINE THE LOCATION OF REMOTE AREAS, HYDRAULIC
 CALCULATION POINTS, AND SYSTEM DIMENSIONS.
 ALL SYSTEM DIMENSIONS SHALL BE IN ACCORDANCE WITH NFPA 13.
 DIMENSIONS AND LOCATIONS OPEN FOR SPRINKLER
 HEADS AND PIPING SHALL BE ACCORDANT
 WITH THE ARCHITECT'S INTENT TO ACCOMMODATE
 THE LOCATION OF REMOTE AREAS, HYDRAULIC
 CALCULATION POINTS, AND SYSTEM DIMENSIONS.
 ALL SYSTEM DIMENSIONS SHALL BE IN ACCORDANCE WITH NFPA 13.
 ALL ELECTRICAL, MECHANICAL, AND PLUMBING
 WORK SHALL BE IN ACCORDANCE WITH THE
 GENERAL CONTRACTOR'S RECORD DRAWINGS.
 ALL ELECTRICAL WORK IS TO BE DONE BY OTHERS.

HEAD LEGEND:
 ○ OBJECT
 MODEL: 01:5601
 59 / 7155
 (K-4.5.8)
 1/2" WHITE PAVENIT
 SEMI-RECESSED ESC.



5 5TH FLOOR (WET)
 TOTAL PROTECTED AREA 5,000 SQ.FT.
 SCALE 3/16" = 1'-0"

DRAWING TITLE:
 OFFICES FOR
 UNUM
 FIRE PROTECTION PLAN
 (NFA 13 2010ed.)
 DRAWING NO.:
 FP-01

TOTAL HEADS ON THIS SHEET 52
 SCALE: 3/16" = 1'-0"
 REVISIONS:
 NO. DATE: DESCRIPTION:
 DATE: DECEMBER 03, 2013
 DESIGNER: JOHN COLLINS
 CHECKER: J. COLLINS
 NIGET LEVEL: IV CERT # 108534
 LOCATION: 5TH FLOOR
 ONE MONUMENT SQ.
 PORTLAND, ME