



**. . . Fire Protection by Computer Design**

DEAN & ALLYN, INC.  
116 LEWISTON ROAD  
GRAY, MAINE 04039  
207-657-5646

Job Name : Bank of America 10th Floor-Light Hazard Area  
Building : 10th Floor Renovations  
Location : Portland, Maine  
System : WX4  
Contract : C1277  
Data File : C1277 BoA 10th Floor.WX4

Hydraulic Design Information Sheet

Name - Bank of America Date - 07-17-2015  
 Location - Portland, Maine  
 Building - 10th Floor Renovations System No. - WX4  
 Contractor - Dean & Allyn, Inc. Contract No. - C1277  
 Calculated By - T. Clarke Drawing No. - 2 of 2  
 Construction: ( ) Combustible (X) Non-Combustible Ceiling Height - 8'-6"  
 Occupancy - Offices

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 900	System Type	Sprinkler/Nozzle
	Density	- 0.10	(X) Wet	Make Reliable
D	Area Per Sprinkler	- 150	( ) Dry	Model G5-56
E	Elevation at Highest Outlet	- 135.167	( ) Deluge	Size 1/2x1/2
S	Hose Allowance - Inside	- 100	( ) Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	- 0	( ) Other	Temp.Rat.155F
G	Hose Allowance - Outside	- 0		

N Note Safety Margin: 19.3 PSI

Calculation Flow Required - 483.8 Press Required - 124.1 At Pump  
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 04-17-2014		Cap. -
T	Time of Test -	Rated Cap.- 500	Elev.-
E	Static Press - 165	@ Press - 71	
R	Residual Press - 142	Elev. - 1	Well
S	Flow - 501		Proof Flow
U	Elevation - 1		

P Location -

L Source of Information - Annual Pump Test Report

C	Commodity N/A	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

E Horizontal Barriers Provided:

# Fittings Used Summary

DEAN & ALLYN, INC.  
Bank of America 10th Floor-Light Hazard Area

Page 2  
Date 07/17/2015

## Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Y	Mechanical Tee	2	4	5	6	8	10.5	12.5	15.5	0	22	0	0	0	0	0	0	0	0	0	0

## Units Summary

Diameter Units           Inches  
Length Units               Feet  
Flow Units                 US Gallons per Minute  
Pressure Units             Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.  
Bank of America 10th Floor-Light Hazard Area

Page 3  
Date 07/17/2015

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
101A	135.167	5.6	7.17	na	15.0	0.1	150	7.0
102A	135.167	5.6	7.75	na	15.59	0.1	150	7.0
103A	135.167	5.6	9.78	na	17.51	0.1	150	7.0
104A	135.167	5.6	11.67	na	19.13	0.1	150	7.0
104B	135.167	5.6	12.01	na	19.41	0.1	150	7.0
105A	135.167	5.6	7.5	na	15.33	0.1	150	7.0
106A	135.167	5.6	7.99	na	15.83	0.1	150	7.0
107A	135.167	5.6	8.7	na	16.52	0.1	150	7.0
108A	135.167	5.6	11.96	na	19.36	0.1	150	7.0
109A	135.167	5.6	12.83	na	20.06	0.1	150	7.0
110A	135.167	5.6	11.67	na	19.13	0.1	150	7.0
111A	135.167	5.6	12.47	na	19.78	0.1	150	7.0
112A	135.167	5.6	14.3	na	21.18	0.1	150	7.0
101	135.667		7.73	na				
102	135.667		8.52	na				
103	135.667		10.78	na				
104	135.667		13.15	na				
105	135.667		8.01	na				
106	135.667		8.81	na				
107	135.667		9.94	na				
108	135.667		13.11	na				
109	135.667		14.51	na				
110	135.667		12.44	na				
111	135.667		13.67	na				
112	135.667		16.46	na				
131	135.667		18.26	na				
132	135.667		18.49	na				
133	135.667		18.54	na				
134	135.667		19.04	na				
135	135.667		19.13	na				
136	135.667		23.18	na				
137	135.667		23.53	na				
138	135.667		24.31	na				
139	135.667		26.35	na				
140	135.667		28.41	na				
141	135.667		29.11	na				
FCV1	135.667		62.13	na	250.0			
PUMP	1.0		124.07	na				

The maximum velocity is 17.86 and it occurs in the pipe between nodes 103 and 131

# Final Calculations - Hazen-Williams - 2007

DEAN & ALLYN, INC.  
Bank of America 10th Floor-Light Hazard Area

Page 4  
Date 07/17/2015

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
101A to 101	15.00 15.0 0.0 15.00	1.049 120.0 0.0765	3E T	6.0 0.0 0.0	4.042 6.000 10.042	7.175 -0.217 0.768			K Factor = 5.60 Vel = 5.57	
						7.726			K Factor = 5.40	
102A to 102	15.59 15.59 0.0 15.59	1.049 120.0 0.0821	2E T	4.0 5.0 0.0	3.042 9.000 12.042	7.750 -0.217 0.989			K Factor = 5.60 Vel = 5.79	
						8.522			K Factor = 5.34	
103A to 103	17.51 17.51 0.0 17.51	1.049 120.0 0.1018	2E T	4.0 5.0 0.0	3.000 9.000 12.000	9.778 -0.217 1.222			K Factor = 5.60 Vel = 6.50	
						10.783			K Factor = 5.33	
104A to 104	19.13 19.13 0.0 19.13	1.049 120.0 0.1199	2E T	4.0 5.0 0.0	5.208 9.000 14.208	11.667 -0.217 1.703			K Factor = 5.60 Vel = 7.10	
						13.153			K Factor = 5.27	
104B to 104	19.41 19.41 0.0 19.41	1.049 120.0 0.1232	3E T	6.0 0.0 0.0	5.042 6.000 11.042	12.010 -0.217 1.360			K Factor = 5.60 Vel = 7.21	
						13.153			K Factor = 5.35	
105A to 105	15.33 15.33 0.0 15.33	1.049 120.0 0.0796	3E T	6.0 0.0 0.0	3.208 6.000 9.208	7.497 -0.217 0.733			K Factor = 5.60 Vel = 5.69	
						8.013			K Factor = 5.42	
106A to 106	15.83 15.83 0.0 15.83	1.049 120.0 0.0845	2E T	4.0 5.0 0.0	3.208 9.000 12.208	7.994 -0.217 1.032			K Factor = 5.60 Vel = 5.88	
						8.809			K Factor = 5.33	
107A to 107	16.52 16.52 0.0 16.52	1.049 120.0 0.0914	2E T	4.0 5.0 0.0	6.917 9.000 15.917	8.704 -0.217 1.455			K Factor = 5.60 Vel = 6.13	
						9.942			K Factor = 5.24	
108A to 108	19.36 19.36 0.0 19.36	1.049 120.0 0.1226	3E T	6.0 0.0 0.0	5.167 6.000 11.167	11.956 -0.217 1.369			K Factor = 5.60 Vel = 7.19	
						13.108			K Factor = 5.35	
109A to 109	20.06 20.06 0.0 20.06	1.049 120.0 0.1308	2E T	4.0 5.0 0.0	5.500 9.000 14.500	12.828 -0.217 1.897			K Factor = 5.60 Vel = 7.45	

# Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.  
Bank of America 10th Floor-Light Hazard Area

Page 5  
Date 07/17/2015

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 20.06									
						14.508			K Factor = 5.27	
110A to 110	19.13 19.13	1.049 120.0 0.1199	3E	6.0 0.0 0.0	2.250 6.000 8.250	11.669 -0.217 0.989			K Factor = 5.60	Vel = 7.10
	0.0 19.13									
						12.441			K Factor = 5.42	
111A to 111	19.78 19.78	1.049 120.0 0.1275	2E T	4.0 5.0 0.0	2.125 9.000 11.125	12.473 -0.217 1.418			K Factor = 5.60	Vel = 7.34
	0.0 19.78									
						13.674			K Factor = 5.35	
112A to 112	21.18 21.18	1.049 120.0 0.1447	2E T	4.0 5.0 0.0	7.417 9.000 16.417	14.300 -0.217 2.375			K Factor = 5.60	Vel = 7.86
	0.0 21.18									
						16.458			K Factor = 5.22	
101 to 102	15.00 15.0	1.049 120.0 0.0764		0.0 0.0 0.0	10.417 0.0 10.417	7.726 0.0 0.796				Vel = 5.57
102 to 103	15.59 30.59	1.049 120.0 0.2856		0.0 0.0 0.0	7.917 0.0 7.917	8.522 0.0 2.261				Vel = 11.36
103 to 131	17.51 48.1	1.049 120.0 0.6599	T	5.0 0.0 0.0	6.333 5.000 11.333	10.783 0.0 7.479				Vel = 17.86
	0.0 48.10									
						18.262			K Factor = 11.26	
104 to 131	38.54 38.54	1.049 120.0 0.4379	T	5.0 0.0 0.0	6.667 5.000 11.667	13.153 0.0 5.109				Vel = 14.31
	0.0 38.54									
						18.262			K Factor = 9.02	
105 to 106	15.33 15.33	1.049 120.0 0.0796		0.0 0.0 0.0	10.000 0.0 10.000	8.013 0.0 0.796				Vel = 5.69
106 to 107	15.84 31.17	1.049 120.0 0.2956		0.0 0.0 0.0	3.833 0.0 3.833	8.809 0.0 1.133				Vel = 11.57
107 to 132	16.52 47.69	1.049 120.0 0.6494	T	5.0 0.0 0.0	8.167 5.000 13.167	9.942 0.0 8.551				Vel = 17.70
	0.0 47.69									
						18.493			K Factor = 11.09	
108 to 109	19.36 19.36	1.049 120.0 0.1226		0.0 0.0 0.0	11.417 0.0 11.417	13.108 0.0 1.400				Vel = 7.19

# Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.  
Bank of America 10th Floor-Light Hazard Area

Page 6  
Date 07/17/2015

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
109 to 133	20.06 39.42	1.049 120.0 0.4566	T	5.0 0.0 0.0	3.833 5.000 8.833	14.508 0.0 4.033				Vel = 14.63
	0.0 39.42					18.541				K Factor = 9.15
110 to 111	19.13 19.13	1.049 120.0 0.1198		0.0 0.0 0.0	10.292 0.0 10.292	12.441 0.0 1.233				Vel = 7.10
111 to 134	19.78 38.91	1.049 120.0 0.4457	Y	5.0 0.0 0.0	7.042 5.000 12.042	13.674 0.0 5.367				Vel = 14.44
	0.0 38.91					19.041				K Factor = 8.92
112 to 135	21.18 21.18	1.049 120.0 0.1446	2E T	4.0 5.0 0.0	9.500 9.000 18.500	16.458 0.0 2.675				Vel = 7.86
	0.0 21.18					19.133				K Factor = 4.84
131 to 132	86.64 86.64	2.635 120.0 0.0220		0.0 0.0 0.0	10.500 0.0 10.500	18.262 0.0 0.231				Vel = 5.10
132 to 133	47.68 134.32	2.635 120.0 0.0501		0.0 0.0 0.0	0.958 0.0 0.958	18.493 0.0 0.048				Vel = 7.90
133 to 134	39.42 173.74	2.635 120.0 0.0800		0.0 0.0 0.0	6.250 0.0 6.250	18.541 0.0 0.500				Vel = 10.22
134 to 135	38.91 212.65	2.635 120.0 0.1162		0.0 0.0 0.0	0.792 0.0 0.792	19.041 0.0 0.092				Vel = 12.51
135 to 136	21.18 233.83	2.635 120.0 0.1387		0.0 0.0 0.0	29.208 0.0 29.208	19.133 0.0 4.050				Vel = 13.76
136 to 137	0.0 233.83	2.635 120.0 0.1388		0.0 0.0 0.0	2.500 0.0 2.500	23.183 0.0 0.347				Vel = 13.76
137 to 138	0.0 233.83	2.635 120.0 0.1387		0.0 0.0 0.0	5.625 0.0 5.625	23.530 0.0 0.780				Vel = 13.76
138 to 139	0.0 233.83	2.635 120.0 0.1386	E	8.237 0.0 0.0	6.458 8.237 14.695	24.310 0.0 2.037				Vel = 13.76
139 to 140	0.0 233.83	2.635 120.0 0.1386	E	8.237 0.0 0.0	6.667 8.237 14.904	26.347 0.0 2.066				Vel = 13.76
140 to 141	0.0 233.83	2.635 120.0 0.1388		0.0 0.0 0.0	5.000 0.0 5.000	28.413 0.0 0.694				Vel = 13.76

# Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.  
Bank of America 10th Floor-Light Hazard Area

Page 7  
Date 07/17/2015

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
141 to FCV1	0.0 233.83	2.635 120.0 0.1386	3E 24.711 T 16.474 S 19.22 B 9.61 Fsp 0.0	146.500 70.015 216.515	29.107 3.000 30.019		** Fixed Loss = 3 Vel = 13.76		
FCV1 to PUMP	250.00 483.83	6.357 120.0 0.0073	8E 140.822 2T 75.44 B 12.573 Fsp 0.0	130.500 228.835 359.335	62.126 59.324 2.624		Qa = 250 ** Fixed Loss = 1 Vel = 4.89		
	0.0 483.83					124.074	K Factor = 43.44		



# Water Supply Curve C

DEAN & ALLYN, INC.  
Bank of America 10th Floor-Light Hazard Area

Page 8  
Date 07/17/2015

City Water Supply:  
C1 - Static Pressure : 165  
C2 - Residual Pressure: 142  
C2 - Residual Flow : 501

Demand:  
D1 - Elevation : 58.108  
D2 - System Flow : 233.828  
D2 - System Pressure : 124.074  
Hose ( Demand ) : 250  
D3 - System Demand : 483.828  
Safety Margin : 19.363

