



June 12, 2015

From: Jim Pickett, NICET IV

To: Tim Biron; RB Allen Co., Inc

Subject: Fire Alarm System Review for Bank of America at One Monument Square, Portland ME

I have performed a review of the fire alarm system design drawings for the Bank of America 9th & 10th floor fit out at One Monument Square, Portland Maine. The submittal package included the floor plans, riser diagram, battery calculations, and cut sheets.

I have found that the revision, dated June 12, 2015, of the fire alarm system design to be code compliant and adequately supports the fire detection, alarm, and notification requirements of this facility.

Jim Pickett

NICET Cert IV #96403 2/99

RB Allen Co., Inc