

SCANNED

970049

FILL IN AND SIGN WITH INK



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine,

PERMIT ISSUED JAN 23 1997 CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME. 22 Jan 97

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location One City Center Use of Building Restaurant/rental No. Stories New Building Existing " Name and address of owner of appliance Bangkok City Restaurant, One City Center, Portland, Me. Installer's name and address Scribner & Iverson, 54 Warren Ave., Portland Telephone 207-797-9441 MS 5512 \$2600.00

General Description of Work

To install Rinnai, #1001 heater - gas fired # MS 5512

\$2600.00 # 2600.00

IF HEATER, OR POWER BOILER

Location of appliance by outside wall Any burnable material in floor surface or beneath? YES If so, how protected? unit designed for wood floor Kind of fuel? Natural gas. Minimum distance to burnable material, from top of appliance or casing top of furnace 10" From top of smoke pipe 0 From front of appliance 3' From sides or back of appliance 2" Size of chimney flue 3" Other connections to same flue no If gas fired, how vented? thru wall Rated maximum demand per hour 38,500 BTU Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? YES

IF OIL BURNER

Name and type of burner Labelled by underwriters' laboratories? Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? Type of floor beneath burner Size of vent pipe Location of oil storage Number and capacity of tanks Low water shut off Make No. Will all tanks be more than five feet from any flame? How many tanks enclosed? Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Height of Legs, if any Skirting at bottom of appliance? Distance to combustible material from top of appliance? From front of appliance From sides and back From top of smokepipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? Forced or gravity? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Via Mail

Amount of fee enclosed? \$35.00

PERMIT ISSUED WITH REQUIREMENTS

APPROVED:

This Permit is being issued with the understanding that it meets the requirements of Chapters 12 & 8 of the City's mechanical code The 2001 BOCA National Mechanical Code 1993

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Signature of Installer H. Haic

INSPECTION FILE APPLICANT'S ASSESSOR'S COPY

