

ELECTRICAL PERMIT

City of Portland, Me.

32-L-002



SCANNED

To the Chief Electrical Inspector, Portland Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical code and the following specification:

Date 13 August 1996

Permit # 16185

LOCATION: 1 City Center

OWNER 1 City Center Assoc.

ADDRESS

1st fl Aquarius Travel

TOTAL EACH FEE

OUTLETS								
	Receptacles		Switches		Smoke Detector		28	.20
FIXTURES	(number of)							5.60
	incandescent		fluorescent				24	.20
	fluorescent strip							.20
SERVICES								
	Overhead				TTL AMPS TO	800		15.00
	Underground					800		15.00
TEMPORARY SERV.								
	Overhead				AMPS OVER	800		25.00
	Underground					800		25.00
METERS	(number of)						1	1.00
MOTORS	(number of)							2.00
RESID/COM	Electric units							1.00
HEATING	oil/gas units							5.00
APPLIANCES	Ranges		Cook Tops		Wall Ovens			2.00
	Water heaters		Fans		Dryers			2.00
Disposals	Dishwasher		Compactors		Others (denote)			2.00
MISC. (number of)	Air Cond/win							3.00
	Air Cond/cent							10.00
	Signs							5.00
	Pools							10.00
	Alarms/res							5.00
	Alarms/com						1	15.00
	Heavy Duty							2.00
	Outlets							
	Circus/Carnv							25.00
	Alterations							5.00
	Fire Repairs							15.00
	E Lights						2	1.00
	E Generators							20.00
TRANSFORMER	Panels						1	4.00
	0-25 Kva							5.00
	25-200 Kva						1	8.00
	Over 200 Kva							10.00
					TOTAL AMOUNT DUE			
	MINIMUM FEE/COMMERCIAL 35.00				MINIMUM FEE	25.00		37.60

INSPECTION:

Will be ready _____

or will call XXXXXXXXXXXX

CONTRACTORS NAME E.S. Boulos Co.

ADDRESS 590 County Rd

TELEPHONE 772-3706

MASTER LICENSE No. 16185

LIMITED LICENSE No.

SIGNATURE OF CONTRACTOR

Thomas M. Duncall

Permit Number 16185
Location 1 City Ctr.
Owner Harris Trust
Date of Permit 8/13/86
Final Inspection 8/29/86
By Inspector [Signature]

PROGRESS INSPECTIONS:

DATE: | REMARKS:

8/15/96 need more clips on cables &
support phone cables BETTER