

Grease Gutters provided? yes

Hood Clearance reduction to Combustibles design /specs:

Min 18"

Duct Clearance reduction to Combustibles design /specs:

Min. 18"

Vibration Isolation System:

Air Velocity within the duct system 2000 FPM

Grease accumulation prevention system:

Cleanouts NONE

Grease Duct enclosure PIPE WRAP where required

Exhaust Termination Roof X Wall \_\_\_\_\_

Fire Suppression System yes

Exhaust fan mounting and clearance from the roof / wall or Combustibles:

10' Min.

Exhaust fan distance from property lines 20'

Exhaust fan distance from other vents or openings 10'

Exhaust fan distance from adjacent buildings 12'

Exhaust fan height above adjoining grade \_\_\_\_\_

### Hood Specs

Style of Hood CANOPY

Type of Filter BAFFLE

Height of filter above nearest cooking surface 48"

Capacity of hood CFM 900 - on 4' + 2800 on 7' Hood

Make up Air system description and capacity

Make up AIR IS FROM CENTRAL SYSTEM  
at 1 CITY CENTER.