Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 03/10/14

	DESCRIPTION	CATALOG #
	›ke Detector w/Base	XP–95P XP95–B6EZ
PID	Monitor Module for Remote Booster Panel	PID–95
	Strobe Unit	STR
	Speaker/Strobe Unit	E50–24MCW–FR
F	Addressable Pull Station	MS–95T

General Notes:

1. ALL WIRING IN ACCORDANCE WITH NATIONAL ELECTRICAL CODE, STATE OF MAINE BUILDING CODE, CITY OF PORTLAND, AND MANUFACTURER'S REQUIREMENTS & RECOMMENDATIONS.
2. ALL ADRESSABLE DEVICES MUST BE INSTALLED IN A HEATED LOCATION.

Wiring Notes:

1. Addressable loop consists of (1) Twisted Pair #16 non-shielded cable from and to an existing addressable device.
2. Speaker circuit consists of (1) Twisted Pair #16 Shielded cable from and to an existing audio/visual device.
3. Strobe circuit consists of (1) 2c #14 cable from and to an existing audio/visual device.

Riser Diagram

Partial Plan First Floor

(Scale as noted on Plan)

DWG NAME: Absolute Health Chiropractic
1st Floor 1 City Center
Portland, ME
Fire Alarm Floor Plan
DWG NAME: FA_1CC1

R.B. Allen Co., Inc.
P.O. BOX 770
131 LAFAYETTE RD
NO. HAMPTON, NH 03862
(603)-964-7264

JOB NAME: Absolute Health Chiropractic
1st Floor 1 City Center
Portland, ME
Fire Alarm Floor Plan
CONTRACTOR: Dirigo Management Company

SCALE: 1/8" = 1'–0" (C Size Plot)

REV.	DESCRIPTION	DATE	DRWN:	RVW'D:
0	Original Issue	1/14	KMB	TRD

PO No.
Absolute Health Chiropractic
1st Floor 1 City Center
Portland, ME
Fire Alarm Floor Plan
DWG NO. FA_1CC1