Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 03/10/14

Gamewell Addressable System
1 City Center
Floor 1 - Absolute Health Chiropractic
Portland, Maine

Click on a Description to View Data Sheet

Item	Qty	Catalog #	Description	Data Sheet
1			**Initiating Devices**	
	7	XP-95P	Addressable Smoke Detector	CS-2054
	7	XP95-B6EZ	Smoke Detector Base	CS-2048
	2	MS-95T	Addressable Manual Pull Station	CS-2053
2			**Indicating Devices/Miscellaneous**	
	5	E50-24MCW-FR	Speaker/Strobe Unit - Wall Mount (Selectable Candela)	S0510
	9	STR	Strobe Unit - Wall Mount (Selectable Candela)	Exceder

3 **Supporting Documentation**

Click on a Description to View Document

System Engineering Review Letter
Strobe Booster Power Supply Standby Battery Calculations
Strobe Maximium Circuit Length Calculations
System Narrative
System Sequence of Operation Matrix
System Service and Warranty
Fire Alarm System Riser Diagram
Fire Alarm System Floor Plans