DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

ONE CITY CENTER ASSOCIATES LLC

PERMIT ID: 2018-00274 **ISSUE DATE:** 03/21/2018

has permission to Modify existing NFPA 13 sprinkler system in tenant space on 2nd floor.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required. A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Michael Russell, MS, Director

Fire Official

Building Official

Located at

1 CITY CTR

CBL: 032 L002001

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

PERMIT ID: 2018-00274

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 or email: buildinginspections@portlandmaine.gov

Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

| City of Portland, Maine - Building or Use Permit | | Permit No: | Date Applied For: | CBL: |
|--|------------------|------------------|-----------------------|----------------------------------|
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 87 | 74-8716 | 2018-00274 | 03/01/2018 | 032 L002001 |
| Proposed Use: Proposed Project Description: | | | | |
| Same. 1st floor, retail, food vendors, offices, restaurant with offices above | Modify floor. | existing NFPA 13 | sprinkler system in t | enant space on 2nd |
| Dept: Fire Status: Approved w/Conditions Residual Note: | eviewer: | Chris Pirone | Approval Da | te: 03/21/2018 Ok to Issue: ☑ |
| Conditions: | | | | |
| Contractor's Material and Test Certificate for Aboveground Piping (NFPA 13 figure 24.1) shall be provided prior to scheduling of the final inspection. | | | | |
| 2) Installation shall be in accordance with the City of Portland Fire Department Regulations and NFPA 13 as published. | | | | |
| 3) Installation shall be in accordance with the City of Portland Fire Department Regulations and NFPA 13 as published. A copy of the State Sprinkler permit with RMS date and signature and the Contractor's Material and Test Certificate for Aboveground Piping (NFPA 13 figure 24.1) shall be provided prior to scheduling of the final inspection. | | | | |
| System acceptance and commissioning must be coordinated with a fire alarm technician and suppression system contractors and the Fire Department. Call 874-8400 to schedule. | | | | |
| Shall comply with NFPA 13 Standard for the Installation of Sprinkler Systems. Shall comply with 2009 NFPA 1 Chapter 13 Fire Protection Systems. | | | | |