DIVISION 16 – ELECTRICAL SPECIFICATION

16010 GENERAL PROVISIONS

(A) THE ARCHITECTURAL GENERAL AND SPECIAL CONDITIONS FOR THE CONSTRUCTION OF THIS PROJECT SHALL BE A PART OF THE ELECTRICAL SPECIFICATIONS. THE ELECTRICAL CONTRACTOR SHALL EXAMINE THE GENERAL AND SPECIAL CONDITIONS BEFORE SUBMITTING THE PROPOSAL.

(B) THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WORK INCLUDED IN THIS SECTION AND THE DELEGATION OF WORK TO THE ELECTRICAL CONTRACTOR SHALL NOT RELIEVE HIM OF THIS RESPONSIBILITY. THE ELECTRICAL CONTRACTOR AND HIS SUBCONTRACTORS WHO PERFORM WORK UNDER THIS SECTION SHALL BE RESPONSIBLE TO THE GENERAL CONTRACTOR.

(C) WHERE ITEMS OF THE GENERAL CONDITIONS OR OF THE SPECIAL CONDITIONS ARE REPEATED IN THIS SECTION OF THE SPECIFICATIONS, IT IS INTENDED TO CALL PARTICULAR ATTENTION TO OR QUALIFY THEM; IT IS NOT INTENDED THAT ANY OTHER PART OF THE GENERAL CONDITIONS OR SPECIAL CONDITIONS SHALL BE ASSUMED TO BE OMITTED IF NOT REPEATED HEREIN.

(D) THE NAMING OF A CERTAIN BRAND OR MAKE OR MANUFACTURER IN THE SPECIFICATIONS IS TO ESTABLISH A QUALITY STANDARD FOR THE ARTICLE DESIRED. THE CONTRACTOR IS RESTRICTED TO THE USE OF THE SPECIFIC BRAND OF THE MANUFACTURER NAMED. HOWEVER, WHERE A SUBSTITUTION IS REQUESTED, A SUBSTITUTION WILL BE PERMITTED ONLY WITH THE WRITTEN APPROVAL OF THE ENGINEER. NO SUBSTITUTE MATERIAL OR EQUIPMENT SHALL BE ORDERED, FABRICATED, SHIPPED OR PROCESSED IN ANY MANNER PRIOR TO THE APPROVAL OF THE ARCHITECT/ENGINEER. THE CONTRACTOR SHALL SUBMIT SUBSTITUTIONS TO THE ENGINEER FOR APPROVAL AT LEAST 30 DAYS PRIOR TO THE DATE WHEN THE APPROVED MATERIAL OR EQUIPMENT SPECIFIED IS REQUIRED. NOTICE OF SUBSTITUTION IS NOT FURNISHED TO THE ENGINEER WITHIN THE TIME DAYS AFTER THE GENERAL CONTRACT IS AWARDED, THEN EQUIPMENT AND MATERIALS NAMED IN THE SPECIFICATIONS ARE TO BE USED.

(E) THE ELECTRICAL CONTRACTOR SHALL FURNISH AND PRESENT FIVE (5) COPIES OF SHOP DRAWINGS OR BROCHURES FOR ALL FIXTURES, EQUIPMENT, AND ACCESSORIES TO THE ENGINEER FOR THE ENGINEER'S APPROVAL. THE ELECTRICAL CONTRACTOR SHALL FURNISH AND PRESENT FIVE (5) COPIES OF A SCHEDULE OF MANUFACTURERS OF ALL MATERIALS FOR WHICH SHOP DRAWINGS OR BROCHURES ARE NOT PRESENTED. NO EQUIPMENT SHALL BE ORDERED, PURCHASED OR INSTALLED PRIOR TO APPROVAL OF THE SHOP DRAWINGS, BROCHURES, AND SCHEDULES. CHECKING IS ONLY FOR GENERAL CONFORMANCES WITH THE DESIGN CONCEPT OF THE PROJECT AND GENERAL COMPLIANCE WITH THE INFORMATION GIVEN IN THE CONTRACT PLANS AND SPECIFICATIONS. CONTRACTOR IS RESPONSIBLE FOR DIMENSIONS WHICH SHALL BE CONFIRMED AND CORRELATED AT THE JOB SITE; FABRICATIONS PROCESSES AND TECHNIQUES OF CONSTRUCTION; COORDINATION OF HIS WORK WITH THAT OF ALL OTHER TRADES AND THE SATISFACTORY PERFORMANCES OF HIS WORK.

(F) THE ELECTRICAL CONTRACTORS SHALL EXAMINE DRAWINGS RELATING TO WORK OF ALL TRADES AND BECOME FULLY INFORMED AS TO THE EXTENT AND CHARACTER OF WORK REQUIRED AND ITS RELATION TO ALL OTHER WORK IN THE PROJECT.

(G) BEFORE SUBMITTING BID, CONTRACTOR SHALL VISIT THE SITE AND EXAMINE AND SPACE CONDITIONS ON WHICH HIS WORK IS IN ANY WAY DEPENDENT FOR THE BEST WORKMANSHIP AND OPERATION ACCORDING TO THE INTENT OF THE SPECIFICATIONS AND DRAWINGS. HE SHALL REPORT TO THE ARCHITECT AND CONDITION WHICH MIGHT PREVENT HIM FROM INSTALLING HIS EQUIPMENT IN THE MANNER INTENDED.

(H) NO CONSIDERATION OR ALLOWANCE WILL BE GRANTED FOR FAILURE TO VISIT SITE, OR FOR ANY ALLEGED MISUNDERSTAND OF MATERIALS TO BE FURNISHED OR WORK TO BE DONE.

(I) THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL ARRANGEMENTS AND COSTS FOR PROVIDING TEMPORARY ELECTRICAL METERING, MAIN SWITCHES, AND DISTRIBUTION PANELS AT THE SITE AS REQUIRED FOR CONSTRUCTION PURPOSES. THE DISTRIBUTION PANELS SHALL BE LOCATED AT THE CENTRAL POINT DESIGNATED BY THE ARCHITECT. THE GENERAL CONTRACTOR SHALL INDICATE PRIOR TO INSTALLATION WHETHER THREE PHASE OR SINGLE-PHASE SERVICE IS REQUIRED.

(J) THE ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL ONE OSHA APPROVED PIGTAIL SOCKET WITH 150-WATT LAMP FOR EVERY 500 SQUARE FEET OF FLOOR SPACE, EVENLY DISTRIBUTED THROUGHOUT THE BUILDING.

(K) THE ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL POWER OUTLETS TO TOTAL ONE FOR EVERY 2000 SQUARE FEET OR PART THEREOF OF FLOOR AREA AND THESE SHALL BE 15-AMP. SINGLE-PHASE RECEPTACLES FOR EITHER 110 OR 220 VOLTS AS DIRECTED BY THE GENERAL CONTRACTOR.

(L) ANY LIGHT OR POWER OUTLETS REQUIRED OVER THE MAXIMUM QUANTITY NOTED ABOVE SHALL BE PAID FOR BY THE CONTRACTOR REQUIRING THE SAME. THE POWER CONSUMPTION SHALL BE PAID FOR BY THE GENERAL CONTRACTOR.

16015 ELECTRICAL DRAWINGS AND REFERENCE SYMBOLS

(A) THE DRAWINGS ARE DIAGRAMATIC AND INDICATE GENERALLY THE LOCATIONS OF MATERIAL AND EQUIPMENT. THESE DRAWINGS SHALL BE FOLLOWED AS CLOSELY AS POSSIBLE. THE ELECTRICAL CONTRACTOR SHALL COORDINATE THE WORK UNDER THIS SECTION WITH THE ARCHITECTURAL, STRUCTURAL, PLUMBING, HEATING AND AIR CONDITIONING, AND THE WORK OF ALL OTHER TRADES FOR EXACT DIMENSIONS, CLEARANCES AND ROUGHING-IN LOCATIONS; THIS CONTRACTOR SHALL COOPERATE WITH ALL TRADES IN ORDER TO MAKE MINOR FIELD ADJUSTMENTS TO ACCOMMODATE THE WORK OF OTHERS.

(B) THE DRAWINGS AND SPECIFICATIONS ARE COMPLEMENTARY, EACH TO THE OTHER, AND THE WORK REQUIRED BY EITHER SHALL BE INCLUDED IN THE CONTRACT AS IF CALLED FOR BY BOTH.

(C) IF DIRECTED BY THE ARCHITECT, THE CONTRACTOR SHALL WITHOUT EXTRA CHARGE, MAKE REASONABLE MODIFICATIONS IN THE LAYOUT AS NEEDED TO PREVENT CONFLICT WITH WORK OF OTHER TRADES OR FOR PROPER EXECUTION OF THE WORK.

(D) ELECTRICAL SYMBOLS USED ON THIS PROJECT ARE SHOWN IN A SYMBOL LIST ON THE ACCOMPANYING WORKING DRAWINGS. THIS LIST SHOWS STANDARD SYMBOLS AND ALL MAY NOT APPEAR ON THE PROJECT DRAWINGS; HOWEVER, WHEREVER THE SYMBOL ON PROJECT DRAWINGS OCCURS, THE ITEM SHALL BE PROVIDED AND INSTALLED.

16020 WORK INCLUDED

(A) THE SCOPE OF THE WORK CONSISTS OF THE FURNISHING AND INSTALLING OF COMPLETE ELECTRICAL SYSTEMS – EXTERIOR AND INTERIOR – INCLUDING MISCELLANEOUS SYSTEMS. THE ELECTRICAL CONTRACTOR SHALL PROVIDE ALL SUPERVISION, LABOR, MATERIALS, EQUIPMENT, MACHINERY, AND ANY AND ALL OTHER ITEMS NECESSARY TO COMPLETE THE SYSTEMS. THE ELECTRICAL CONTRACTOR SHALL NOTE THAT ALL ITEMS OF EQUIPMENT ARE SPECIFIED IN THE SINGULAR; HOWEVER THE CONTRACTOR SHALL PROVIDE AND INSTALL THE NUMBER OF ITEMS OR EQUIPMENT AS INDICATED ON THE DRAWINGS AND AS REQUIRED FOR COMPLETE SYSTEMS.

(B) IT IS THE INTENTION OF THE SPECIFICATIONS AND DRAWINGS TO CALL FOR FINISHED WORK, TESTED, AND READY FOR OPERATION.

(C) ANY APPARATUS, APPLIANCE, MATERIAL OR WORK NOT SHOWN ON DRAWINGS BUT MENTIONED IN THE SPECIFICATIONS, OR VICE VERSA, OR ANY INCIDENTAL ACCESSORIES NECESSARY TO MAKE THE WORK COMPLETE AND PERFECT IN ALL RESPECTS AND READY FOR OPERATION EVEN IF NOT PARTICULARLY SPECIFIED, SHALL BE FURNISHED AND DELIVERED AND INSTALLED BY THE CONTRACTOR WITHOUT ADDITIONAL EXPENSE TO THE OWNER.

(D) MINOR DETAIL NOT USUALLY SHOWN OR SPECIFIED, BUT NECESSARY FOR PROPER INSTALLATION AND OPERATION, SHALL BE INCLUDED IN THE CONTRACTOR'S ESTIMATE, THE SAME AS IF HEREIN SPECIFIED OR SHOWN.

(E) WITH SUBMISSION OF BID, THE ELECTRICAL CONTRACTOR SHALL GIVE WRITTEN NOTICE TO THE ARCHITECT OF ANY MATERIALS OR APPARATUS BELIEVED INADEQUATE OR UNSUITABLE, IN VIOLATION OF LAWS, ORDINANCES, RULES, AND NECESSARY ITEMS OR WORK OMITTED. IN THE ABSENCE OR SUCH WRITTEN NOTICE, IT IS MUTUALLY AGREED THE CONTRACTOR HAS INCLUDED THE COST OF ALL REQUIRED ITEMS IN HIS PROPOSAL, AND THAT HE WILL BE RESPONSIBLE FOR THE APPROVED SATISFACTORY FUNCTIONING OF THE ENTIRE SYSTEM WITHOUT EXTRA COMPENSATION.

16025 WORK NOT INCLUDED

(A) THE FOLLOWING EQUIPMENT ITEMS AND WORK SHALL BE THE RESPONSIBILITY OF OTHERS.

1. MOTORS AND CONTROLS, UNLESS INDICATED OTHERWISE, SHALL BE FURNISHED BY OTHERS, BUT SHALL BE INSTALLED AND CONNECTED BY THE ELECTRICAL CONTRACTOR AS INDICATED ON THE DRAWINGS.
2. TELEPHONE SYSTEMS WIRES, CABLE, EQUIPMENT, AND INSTRUMENTS SHALL BE FURNISHED AND INSTALLED BY THE VENDOR OR TELEPHONE COMPANY.
3. ELEVATOR SIGNAL AND CONTROL WIRING BEYOND SERVICE FEEDER NOTED ON DRAWINGS SHALL BE PROVIDED AND INSTALLED BY OTHERS.
4. CONTROLS FOR MOTORS ON MECHANICAL EQUIPMENT UNLESS INDICATED OTHERWISE, WILL BE FURNISHED BY OTHERS BUT SHALL BE INSTALLED AND WIRED BY THE ELECTRICAL CONTRACTOR.

16060 CODES AND FEES

(A) ALL MATERIALS AND WORKMANSHIP SHALL COMPLY WITH ALL APPLICABLE CODES, SPECIFICATIONS, LOCAL ORDINANCES, INDUSTRY STANDARDS, UTILITY COMPANY AND FIRE INSURANCE CARRIER'S REQUIREMENTS.

(B) IN CASE OF DIFFERENCE BETWEEN THE BUILDING CODES SPECIFICATIONS, STATE LAWS, LOCAL ORDINANCES, INDUSTRY STANDARDS, UTILITY COMPANY REGULATIONS, FIRE INSURANCE CARRIER'S REQUIREMENTS, AND THE CONTRACT DOCUMENTS, THE MOST STRINGENT SHALL GOVERN. THE CONTRACTOR SHALL PROMPTLY NOTIFY THE ARCHITECT IN WRITING OF ANY SUCH DIFFERENCE.

(C) NONCOMPLIANCE: SHOULD THE CONTRACTOR PERFORM ANY WORK THAT DOES NOT COMPLY WITH THE REQUIREMENTS OF THE APPLICABLE BUILDING CODES, STATE LAWS, LOCAL ORDINANCES, INDUSTRY STANDARDS FIRE INSURANCE CARRIER'S REQUIREMENTS, AND UTILITY COMPANY REGULATIONS, HE SHALL BEAR THE COST ARISING IN CORRECTING ANY SUCH DEFICIENCIES.

(D) APPLICABLE CODES AND ALL STANDARDS SHALL INCLUDE ALL STATE LAWS, LOCAL ORDINANCES, UTILITY COMPANY REGULATIONS AND THE APPLICABLE REQUIREMENTS OF THE FOLLOWING NATIONALLY ACCEPTED CODES AND STANDARDS:

1. BUILDING CODES
   A. NATIONAL BUILDING CODES
   B. LOCAL BUILDING CODE
   C. NATIONAL ELECTRIC CODES
   D. STATE ELECTRICAL CODE
   E. LOCAL MUNICIPAL ELECTRICAL CODE
2. INDUSTRY STANDARDS, CODES, AND SPECIFICATIONS
   A. AMCA – AIR MOVING AND CONDITIONING ASSOCIATION
   B. ASHRAE – AMERICAN SOCIETY OF HEATING, REFRIGERATION, AND AIR CONDITIONING ENGINEERS
   C. ASME – AMERICAN SOCIETY OF MECHANICAL ENGINEERS
   D. ASTM – AMERICAN SOCIETY FOR TESTING AND MATERIALS
   E. EIA – ELECTRONIC INDUSTRIES ASSOCIATION
   F. IEEE – INSTITUTE OF ELECTRICAL AND ELECTRONIC ENGINEERS
   G. IPCEA – INSULATED POWER CABLE ENGINEERS' ASSOCIATION
   H. NEC – NATIONAL ELECTRIC CODE (NFPA NO. 70–2005) AS INDICATED IN THE PAINTING SPECIFICATIONS, COLOR ELECTED BY THE ARCHITECT.
   I. NBS – NATIONAL BUREAU OF STANDARDS
   J. NEMA – NATIONAL ELECTRICAL MANUFACTURER'S ASSOCIATION
   K. NFPA – NATIONAL FIRE PROTECTION ASSOCIATION
   L. ANSI – AMERICAN NATIONAL STANDARDS INSTITUTE
   M. UL – UNDERWRITERS' LABORATORIES
3. INSURANCE CARRIERS
   A. FIA – FACTORY INSURANCE ASSOCIATION
   B. FMED – FACTORY MUTUAL ENGINEERING DIVISION

16070 BASIC ELECTRICAL MATERIALS AND METHODS

16101 GENERAL

(A) ALL MATERIALS AND EQUIPMENT SHALL BE NEW, UNDAMAGED, AND SHALL BEAR THE UL LABEL OF APPROVAL AND SHALL BE LISTED FOR USE IN EACH SPECIFIC LOCATION, UNLESS APPROVAL DOES NOT APPLY.

(B) SAMPLES OF ALL MATERIALS PROPOSED FOR USE SHALL BE PRESENTED TO THE ENGINEER FOR HIS APPROVAL WHEN REQUESTED.

(C) EQUIPMENT FINISH: ALL ELECTRICAL EQUIPMENT SHALL BE FURNISHED FACTORY PAINTED FOR FINISHED WITH TWO COATS OF HIGH GRADE ENAMEL AND IN THE MANUFACTURER'S STANDARDS COLORS UNLESS OTHERWISE SPECIFIED.

1. UNPAINTED EQUIPMENT AND MATERIALS, EXCEPT CONDUIT, SHALL BE CLEANED AND PRIMED TO BE PAINTED BY THE PAINTING CONTRACTOR IN ACCORDANCE WITH THE PAINTING SECTION OF ARCHITECTURAL SPECIFICATIONS.
2. THE COLORS OF ALL EXPOSED ELECTRICAL MATERIAL AND APPARATUS SHALL BE AS SELECTED BY THE OWNER.
3. EXPOSED CABINETS AND BOXES (FRONTS AND DOORS) SHALL BE PAINTED WITH TWO COATS OF HIGH GRADE ENAMEL.

16111 CONDUITS

(A) CONDUIT SIZES SHALL BE AS INDICATED ON THE DRAWINGS, OR MINIMUM IN ACCORDANCE WITH NEC, INCLUDING PROVISION

INCH CONDUIT MAYBE USED.

(B) SPECIAL CONDUIT FITTINGS SHALL BE APPROPRIATE FOR EACH APPLICATION.

(C) CONDUIT SYSTEMS SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITION OR THE NEC AND SHALL BE INSTALLED IN A NEAT, WORKMANLIKE MANNER.

(D) THE ENTIRE CONDUIT SYSTEM SHALL BE INSTALLED TO PROVIDE A CONTINUOUS BOND THROUGHOUT THE SYSTEM.

(E) ELECTRICAL METALLIC TUBING (EMT) MAY BE USED FOR SATELITE CLOSET PANEL FEEDERS, HOME RUNS, AND RACEWAYS OTHER THAN FOR SERVICE ENTRANCE AND MAIN FEEDERS UNLESS PROHIBITED BY THE NEC OR LOCAL ORDINANCES. EMT SHALL BE UL APPROVED, GALVANIZED INSIDE AND OUTSIDE, COMPLYING WITH ASA C-80.3 FOR ZINC COATED EMT WITH FITTINGS OF THE SAME TYPE MATERIAL AND FINISH, AND OF THE PRESSURE CONNECTED TYPE.

(F) ALL CONDUIT JOINTS SHALL CUT SQUARE, THREADED, REAM SMOOTH, AND DRAWN UP TIGHT. BENDS OR OFFSETS SHALL BE MADE WITH AN APPROVED BENDER OR HICKEY, OR HUB-TYPE CONDUIT FITTINGS. NUMBER OF BENDS PER RUN SHALL CONFORM TO THE NEC LIMITATIONS.

(G) CONCEALED CONDUITS SHALL BE RUN IN A DIRECT LINE WITH LONG SWEEP BENDS AND OFFSETS. EXPOSED CONDUITS SHALL BE PARALLEL TO AND AT RIGHT ANGLES TO BUILDING LINES, USING CONDUIT FITTINGS FOR ALL TURNS AND OFFSETS.

(H) METAL CLAD (MC) MAY BE USED FOR BRANCH CIRCUITS. NO CONDUIT PROVIDED MUST INCLUDE SEPARATE BONDED GREEN GROUND WIRE. GROUND. ISOLATED GROUND CIRCUITS SHALL CONTAIN TWO GREEN GROUND WIRES, ONE FOR EQUIPMENT GROUND AND ONE FOR ISOLATED GROUND.

(I) EXPOSED CONDUITS SHALL BE SECURELY FASTENED IN PLACE ON MAXIMUM 5' FOOT INTERVALS; AND HANGERS, SUPPORTS OR FASTENERS SHALL BE PROVIDED AT EACH ELBOW AND AT THE END TO EACH STRAIGHT RUN TERMINATING AT A BOX OR CABINET.

(J) AC CONDUIT OR BX CONDUIT MAY NOT BE USED UNLESS PROVIDED WITH FULL AWG# 12 OR LARGER GREEN GROUND WIRE. NOT I.G. CIRCUITS MUST HAVE TWO GREEN GROUND WIRES; ONE FOR EQUIPMENT GROUND AND ONE FOR I.G. GROUND.

16120 WIRES AND CABLES

(A) WIRE AND CABLE SHALL MEET ALL STANDARDS AND SPECIFICATIONS APPLICABLE, AND SHALL BE IN CONFORMANCE WITH THE LATEST EDITION OF THE NEC. INSULATED WIRE AND CABLE SHALL HAVE SIZE, TYPE OF INSULATION, VOLTAGE AND MANUFACTURER'S NAME PERMANENTLY MARKED ON OUTER COVERING AT REGULAR INTERVALS NOT EXCEEDING FOUR FEET. ALL WIRE AND CABLE SHALL BE DELIVERED IN COMPLETE COILS OR REELS WITH IDENTIFYING TAGS, STATING SIZE, TYPE OF INSULATION, ETC.

(B) WIRE AND CABLE SHALL BE SUITABLY PROTECTED FROM WEATHER AND OTHER DAMAGE DURING STORAGE AND HANDLING, AND SHALL BE IN FIRST-CLASS CONDITION AFTER INSTALLATION.

(C) CONDUCTORS SHALL BE SOFT DRAWN COPPER, ASTM B3 FOR SOLID WIRE, ASTM B8 FOR STRANDED CONDUCTORS. CONDUCTOR WIRE SIZES SHALL BE AMERICAN WIRE GAUGE (AWG). #6 AND LARGER OF STRANDED CONSTRUCTION; #8 AND SMALLER OF SOLID CONSTRUCTION.

(D) WIRE AND CABLE SHALL BE FACTORY COLOR-CODED WITH A SEPARATE COLOR FOR EACH PHASE AND NEUTRAL USED CONSISTENTLY THROUGHOUT THE SYSTEM. COLOR-CODING SHALL BE AS REQUIRED BY THE NEC.

(E) ALL CONDUCTORS SHALL BE RATED 600 VOLTS, UNLESS OTHERWISE SPECIFIED OR SHOWN ON THE DRAWINGS, OR FOR ELECTRONIC OR COMMUNICATION USE.

(F) CONDUCTORS FOR LIGHTING, RECEPTACLE, AND POWER BRANCH CIRCUITS, FEEDERS, AND SUBFEEDERS SIZE #1 AND SMALLER SHALL BE TYPE THHN.

(G) CONDUCTORS FOR FEEDERS AND SUBFEEDERS SIZE #1/0 AND LARGER SHALL BE TYPE THHN.

(H) BRANCH CIRCUITS WITHIN ALL ELECTRIC HEATER ELEMENTS SUCH AS ELECTRIC DUCT COILS, BASEBOARD RADIATION, AND CABINET UNIT HEATERS SHALL BE TYPE THHN HEAT RESISTANT, THERMOPLASTIC INSULATED, MAXIMUM OPERATING TEMPERATURE 90°C (194°F).

(I) UNDERGROUND FEEDER AND BRANCH CIRCUIT WIRE FOR DIRECT BURIAL IN EARTH OR IN CONDUIT SHALL BE TYPE UF FOR USE IN WET OR DRY LOCATIONS.

(J) FOR ANY SPECIAL USE NOT COVERED HERE ABOVE, COMPLY WITH THE NEC IN CONDUCTOR USE.

16121 WIRE CONNECTIONS

(A) JOINTS ON BRANCH CIRCUITS SHALL OCCUR ONLY WHERE SUCH CIRCUITS DIVIDE AS INDICATED ON PLANS AND SHALL CONSIST OF ONE THROUGH CIRCUIT TO WHICH SHALL BE SPLICED THE BRANCH FROM THE CIRCUIT. IN NO CASE SHALL JOINTS IN BRANCH CIRCUITS BE LEFT FOR THE FIXTURE HANGER TO MAKE. NO SPLICES SHALL BE MADE IN CONDUCTOR EXCEPT AT OUTLET BOXES, JUNCTION BOXES OR SPLICE BOXES.

(B) ALL JOINTS OR SPLICES FOR #10 AWG OR SMALLER SHALL BE MADE WITH UL APPROVED WIRE NUTS OR COMPRESSION TYPE CONNECTORS.

(C) ALL JOINTS OR SPLICES FOR #8 AWG OR LARGER SHALL BE MADE WITH A MECHANICAL COMPRESSION CONNECTOR. AFTER THE CONDUCTORS HAVE BEEN MADE MECHANICALLY AND ELECTRICALLY SECURE, THE ENTIRE JOINT OR SPLICE SHALL BE COVERED WITH SCOTCH #33 TAPE OR APPROVED EQUAL TO MAKE THE INSULATION OF THE CONDUCTORS. THE CONNECTOR SHALL BE UL APPROVED.

16125 PULLING CABLES

(A) INSTALL CONDUCTORS IN ALL RACEWAYS AS REQUIRED, UNLESS OTHERWISE NOTED, IN A NEAT AND WORKMANLIKE MANNER. TELEPHONE CONDUITS AND EMPTY CONDUITS AS NOTED, SHALL HAVE A #14 GALVANIZED PULL WIRE LEFT IN PLACE FOR FUTURE USE.

(B) CONDUCTORS SHALL BE COLOR CODED IN ACCORDANCE WITH THE NEC. MAINS, FEEDERS, SUBFEEDERS SHALL BE TAGGED IN ALL PULL, JUNCTION, AND OUTLET BOXES AND IN THE GUTTER OF PANELS WITH APPROVED CODE TYPE WIRE MARKERS.

(C) NO LUBRICANT OTHER THAN POWDERED SOAPSTONE OR APPROVED PULLING COMPOUND MAY BE USED TO PULL CONDUCTORS.

(D) AT LEAST EIGHT (8) INCHES OF SLACK WIRE SHALL BE LEFT IN EVERY OUTLET BOX WHETHER IT BE IN USE OR LEFT FOR FUTURE USE.

(E) ALL CONDUCTORS AND CONNECTIONS SHALL TEST FREE OF GROUNDS, SHORTS AND OPENS DURING THE TURNING THE JOB OVER TO THE OWNER.

(F) PULL BOXES REQUIRED IN RUNS OVER 100 FEET OR WHEN MORE THAN THREE 90-DEGREE BENDS ARE USED, OR AS INDICATED ON THE DRAWINGS.

(G) FEEDERS ARE TO BE RUN ABOVE GROUND TO ALL POWER PANELS AND LIGHTING PANELS, UNLESS INDICATED OTHERWISE ON DRAWINGS.

(H) CONDUIT TERMINATING INSIDE OF PRESTRESSED CONCRETE PANEL VOIDS SHALL BE PROVIDED WITH NECESSARY BUSHINGS TO PREVENT DAMAGE TO WIRING RUN IN VOIDS.

(I) WHERE MOTORS CONDUIT TERMINAL BOXES FEEDERS SHALL BE CONNECTED TO SAME BY FLEXIBLE MEANS.

(J) ALL MOTORS WITH SLIDING BASE MOUNTINGS SHALL HAVE NOT LESS THAN 18 INCHES NOR MORE THAN 6 FEET OF CONDUIT CONNECTING RIGID CONDUIT FEED TO MOTOR TERMINAL BOX.

(K) CONDUCTORS SPLICES SHALL BE MADE ONLY IN JUNCTION BOXES, TERMINAL BOXES, OR PULL BOXES.

16133 OUTLET BOXES

(A) ALL OUTLET BOXES FOR CONCEALED WIRING SHALL BE SHEET METAL, GALVANIZED OR CADMIUM PLATED, AT LEAST 1-¾ INCHES DEEP, SQUARE OR GANGED, OF SIZE TO ACCOMMODATE DEVICES AND NUMBER OF CONDUCTORS NOTED. BOXES SHALL BE EQUIPPED WITH PLASTER RING OR COVER AS NECESSARY.

(B) BOXES FOR EXPOSED WIRING SHALL BE MALLEABLE IRON, CADMIUM FINISH, OR CAST ALUMINUM ALLOY, AND SHALL NOT BE LESS THAN 4 INCHES SQUARE BY 1 ½ INCHES DEEP UNLESS OTHERWISE NOTED.

(C) FIXTURES OUTLET BOXES SHALL BE MINIMUM 4" IN OCTAGONAL AND, WHERE REQUIRED AS OUTLET AND JUNCTION BOXES, THEY SHALL BE 4–11/16" INCHES BY 2–1/8" INCHES DEEP.

(D) OUTLET BOXES FOR CONCEALED TELEPHONE AND SIGNALING SYSTEMS SHALL BE OF THE 4 INCH SQ. TYPE WITH PLASTER COVER AND BUSHED-OPENING COVER PLATE. SEE DETAIL ON DRAWINGS.

(E) OUTLET BOXES FOR HAZARDOUS AREAS SHALL BE EXPLOSION PROOF WITH APPROPRIATE FITTINGS, SEALOFFS, ETC.

(F) BOXES FOR FLOOR OUTLETS SHALL BE OF THE CAST-METAL THREADED–CONDUIT–ENTRANCE, WATERPROOF TYPE WITH MEANS FOR ADJUSTING COVER PLATE TO FINISHED FLOOR LEVEL. BOXES SHALL BE APPROXIMATELY 4 INCHES IN DIAMETER AND 3–¾" INCHES DEEP, WITH AN APPROVED GASKET OR SEAL BETWEEN ADJUSTING RING AND BOX.

16134 PULL AND JUNCTION BOXES

(A) THE ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL JUNCTION BOXES AND PULL BOXES WHERE INDICATED ON THE DRAWINGS, OR AS REQUIRED BY THE NEC, OR WHERE NECESSARY TO FACILITATE PULLING IN WIRES AND CABLES WITHOUT DAMAGE.

(B) BOXES SHALL BE FORMED FROM SHEET STEEL, WITH CORNERS FOLDED IN SECURELY WELDED, WITH INCH INWARD FLANGE ON ALL FOUR EDGES, WITH BOX DRILLED FOR MOUNTING, AND WITH FLANGE DRILLED FOR ATTACHMENT OF COVER. BOX SHALL BE GALVANIZED AFTER FABRICATION. COVER SHALL BE MADE OF ONE PIECE GALVANIZED STEEL AND PROVIDED WITH ROUND HEAD BRASS MACHINE SCREWS FOR FASTENING TO BOX. BOX AND COVER SHALL BE MADE OF CODE GAUGE STEEL, OR HEAVIER AS SPECIFIED. BOXES SHALL BE A MINIMUM OF 4–¾" INCHES DEEP, AND SIZED AS REQUIRED TO MEET NEC REQUIREMENTS, BUT LARGER AS SPECIFIED, UTILIZING MANUFACTURER' STANDARD SIZE, OR NEXT LARGER TO MEET DIMENSIONAL REQUIREMENTS.

16140 WIRING DEVICES

AND CONTROL DEVICES, (EXCEPT SIGNAL AND TELEPHONE OUTLETS PROVIDED BY CABLE VENDOR). PLATES SHALL BE SELECTED BY ARCHITECT.

(C) WHEN DEVICES ARE INSTALLED IN EXPOSED OUTLET BOXES, THE PLATES OR COVERS SHALL BE OF A TYPE DESIGNED FOR THE BOXES.

(D) WHERE LIGHTING BRANCH CIRCUITS ARE TO BE CONTROLLED BY A DIMMING DEVICE, THEY SHALL BE AS MANUFACTURED BY LUTRON WITH RATING AND RANGE OF DIMMER AS INDICATED ON THE DRAWINGS OR BY THE CALCULATED LOAD ON THE CIRCUIT.

(E) TIME SWITCHES SHALL BE FURNISHED AND INSTALLED WHERE CALLED FOR ON THE DRAWINGS AND SHALL BE MANUFACTURED BY WATTSTOPPER.

(F) OUTLETS AND CIRCUITS INDICATED BY THE APPROPRIATE SYMBOL ON THE DRAWINGS SHALL BE CONTROLLED BY A REMOTE CONTROL PACKAGE RELAY SYSTEM AS MANUFACTURED BY WATTSTOPPER. THE SYSTEM SHALL BE COMPLETE WITH ALL RELAYS, SWITCHES, MOTH SWITCHES, POWER SUPPLY, OCCUPANCY SENSORS, ETC.

16190 SUPPORTING DEVICES

(A) THE ELECTRIC CONTRACTOR SHALL PROVIDE AND INSTALL METALLIC SUPPORTS NOT MORE THAN EIGHT FEET APART OR AS REQUIRED FOR THE PROPER INSTALLATION OF RACEWAY SYSTEMS AND ALL OTHER EQUIPMENT INSTALLED UNDER THIS DIVISION OR THE CONTRACT.

(B) CONDUIT SHALL BE SUPPORTED ON APPROVED TYPES OF WALL BRACKETS, CEILING TRAPEZES, STRAP HANGERS OR PIPE SUPPORTS. SECURE BY MEANS OF TOGGLE BOLTS IN HOLLOW MASONRY WALLS AND CEMENT WALLS. EXPANSION BOLTS WILL BE USED IN CONCRETE OR BLOCK MACHINE SCREWS ON METAL SURFACES AND WOOD SCREWS ON WOOD CONSTRUCTION.

(C) CONDUIT SHALL BE SECURELY FASTENED TO ALL SHEET METAL OUTLETS; JUNCTION AND PULL BOXES WITH TWO GALVANIZED STEEL LOCKNUTS WHERE ENTERING THROUGH KNOCKOUTS. BOXES SHALL BE SUPPORTED INDEPENDENTLY THROUGH TO PERMIT THE BUILDING STRUCTURE TO MOVE WITHOUT STRAIN TO THE CONDUIT SYSTEM. AFTER WHICH THE LOCKNUTS SHALL BE MADE TIGHT SUFFICIENTLY TO DRAW THEM INTO FIRM ELECTRICAL CONTACT WITH THE OUTLET BOX.

(D) THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL CONCRETE PADS, SUPPORTS, PIERS, BASES, FOUNDATIONS, AND ENGAGEMENT REQUIRED FOR THE ELECTRICAL EQUIPMENT AND CONDUIT. THE CONCRETE PADS FOR THE ELECTRICAL EQUIPMENT SHALL BE SIX INCHES LARGER ALL AROUND THAN THE BASE OF THE EQUIPMENT UNLESS SPECIFICALLY INDICATED OTHERWISE.

16195 ELECTRICAL IDENTIFICATION

(A) THE ELECTRICAL CONTRACTOR SHALL MAINTAIN ACCURATE RECORDS OF ALL DEVIATIONS IN WORK AS ACTUALLY INSTALLED FROM WORK INDICATED ON THE DRAWINGS. ON COMPLETION OF THE PROJECT, TWO (2) COMPLETE SETS OF MARKED–UP PRINTS SHALL BE DELIVERED TO THE ARCHITECT. MARKED–UP PRINTS SHALL HAVE ELECTRICAL CONTRACTOR (EC) LOGO WITH ENGINEERS LOGO DELETED FROM DRAWINGS.

(B) PROVIDE A RIGID PHENOLIC PLASTIC NAMEPLATE WITH 1/8–INCH ENGRAVED LETTER; MOUNT ON EACH STARTER, DISCONNECT SWITCH PUSHBUTTON STATION, POWER AND LIGHTING PANEL, AND AT EACH CEILING OR WALL ACCESS PANEL TO ELECTRICAL WORK. ATTACH NAMEPLATES WITH SELF–TAPPING SHEET METAL SCREWS.

16199 ELECTRONIC EQUIPMENT

(A) THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR THE INSTALLATION AND CONNECTION OF A PROPER POWER SUPPLY TO ALL ELECTRONIC EQUIPMENT FURNISHED UNDER OTHER SECTIONS. HE SHALL VERIFY ALL VOLTAGE, FREQUENCY, ETC., REQUIREMENTS PRIOR TO ENERGIZING THE CIRCUIT. THOSE INSTALLING THE EQUIPMENT WILL BE RESPONSIBLE FOR THE PROPER OPERATION OF THE EQUIPMENT PROVIDED THE PROPER POWER SUPPLY CIRCUIT IS INSTALLED BY THE ELECTRICAL CONTRACTOR.

16400 SERVICE AND DISTRIBUTION

16440 DISCONNECT SWITCHES

(A) THE ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL SAFETY SWITCHES AS INDICATED ON THE DRAWINGS OR AS REQUIRED. ALL SAFETY SWITCHES SHALL BE GENERAL DUTY AND UL LISTED. THE SWITCHES SHALL BE FUSED SAFETY SWITCHES (FSS) OR NON–FUSED SAFETY SWITCHES (NFSS) AS SHOWN ON THE DRAWINGS OR REQUIRED AND SHALL BE MANUFACTURED BY SIEMENS.

(B) SWITCHES SHALL HAVE A OVER–THE–CENTER OPERATING HANDLE AND MECHANISM WHICH SHALL BE AN INTEGRAL PART OF THE BODY. PADLOCKING PROVISIONS SHALL BE PROVIDED FOR PADLOCKING IN THE OFF POSITION. ALL LIVE PARTS SHALL BE